Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 12/22/17

Fire Alarm System
12 Westfield Street, Portland, Maine 04104

SCOPE of WORK: The submittal for this permit is to upgrade and enhance the existing fire alarm system for the building located at 12 Westfield Street. The system will be installed as indicated by the design layout file LS1 Life Safety Plan Fire Alarm Drawing. The installation will happen soon after the approval. The existing system is a conventional fire with only sprinkler device monitoring. The new system will have manual initiation at exits, sprinkler device monitoring and occupant notification.

The system has the following features:

Addressable control panel

LED Annunciator located at the front entrance

Addressable initiation devices (including manual and automatic initiation)

Occupant notification devices