NORTH

NOTES:
1. VERIFY EXISTING CONDITIONS IN FIELD AND NOTIFY ENGINEER OF ANY DISCREPANCIES.
2. VERIFY EXACT CHILLER DIMENSIONS WITH MANUFACTURER
3. FILL ANY OPENINGS IN EXISTING CMU WALLS UNDER NEW CHILLER UNITS SOLID WITH MASONRY & GROUT FOR CONTINUOUS BEARING
4. CONNECTION OF CHILLER UNIT TO WOOD CURB NOT DESIGNED BY CASCO BAY ENGINEERNG

STATE OF MAINE
ANTHONY DUMAIS
No. 12851
LICENSED
PROFESSIONAL ENGINEER
Anthony Dumais

PARTIAL ROOF FRAMING PLAN

SCALE: 1/8"=1'-0" | 1

CITY OF PORTLAND, MAINE — RESURGAM

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 08/02/16
WW

CLIENT:
JAY VILLANI
20 SALEM STREET
PORTLAND, ME 04102

BUNKER BREWING
NEW CHILLER UNIT
17 WESTFIELD STREET
PORTLAND, MAINE

ISSUE

No.	DATE	DESCRIPTION
0	5-24-16	ISSUED FOR CONSTRUCTION

SHEET TITLE:
PARTIAL ROOF FRAMING PLAN

DESIGNED:	TD
DRAWN:	TD
DATE:	3-16-16
PROJECT No:	16-038

SK1