389 Congress St.
Portland, ME 04101
Phone: (207) 874-8700
Fax: (207)874-8716

facsimile transmittal

To: Gawron Architects **From:** Mike Nugent

Fax: 883-0361 **Date:** November 5, 2001

Phone: 883-6307 **Pages:** 8

Re: 100 Sewall St/ #99607 **CC:**

☐ **Urgent** ☐ **For Review** ☐ **Please Comment** ☑ **Please Reply** ☐ **Please Recycle**

Notes: Please find attached Section 1705 of the 1999 BOCA Code. Please submit the report of Special Inspections as required by 1705.1.1 for review and approval. I was unable to quantify the fire rating of the bearing wall and roof assemblies, please provide that information as well. Also the attached are certifications from Stanley Gawron are for the 1996 Code not the 1999 Code. Please correct this.

Thanks!