
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager KARGAR MOHAMMED &		Inspector Tom Markley	Inspection Date 2/17/2005
Location 47 DOUGLASS ST	CBL 078 C019001	Status Re-Inspect 30 Days	Inspection Type Complaint-Housing Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-108.3	Interior	3	3	Front room	
Violation:	Exterior windows, doors and skylights				
Notes:	Window cracked / broken				
2) 6-114.3	Interior	3	3	Various locations	
Violation:	Maintenance of equipment.				
Notes:	Various discontinued radiator pipes not capped				
3) 6-108.2	Interior	3	3	Rear Hall	
Violation:	Interior floors, walls, ceilings and doors				
Notes:	Missing Ceiling panel				

Comments: