

Request for Clarification of Information

Address: 142 Douglass Street

Permit #: 2017-00352

Date: 4/18/2017

Reviewer: Greg Gilbert

1. Please make sure that all copies/scans are fully readable ✓
- ✓ 2. Submit a plan / section showing the framing and the connection details of the mudroom *Cross Section*
- ✓ 3. Specify the ties and ceiling / roof framing
4. Will the ceiling be closed or open framing? *Yes, ceiling will be closed or open Framing with Sheetrock*
5. Specify the sheathing to be used on the floor, walls and roof *7/16" ZIPboard wall sheathing & 5/8" roof ZIPboard sheathing*
- ✓ 6. Show the porch framing and connections to the mudroom
7. Will the mudroom be insulated space? *Yes, R-21 in walls & 12" Fiberglass in ceiling & Fiberglass 9 1/4" in Floor*
- ✓ 8. Specify the mechanical fasteners and connection.