Reviewed for Code Compliance
Inspections Division
Date: 06/01/16

~All window and door headers in exterior bearing walls to be 2-2x10.
This meets or exceeds allowable span of 8'5" for building width of <20'
and 7'3" for a building width of <28' according to Table 502.5(1) in irc 2009.

SOFTPLAN
ARCHITECTURAL DESIGN SOFTWARE

BASSETT CUSTOM HOME BUILDERS INC
DURHAM, MAINE
BBASSETT9105@GMAIL.COM 207.212.9105

TERRY DURREL AND MARK ROGERS

HOPE HOUSE RENOVATION

563 ST JOHN STREET
PORTLAND, MAINE