

CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager NICOLAI C THOMAS &		Inspector Tom Markley	Inspection Date 6/29/05
Locatation 37 KENWOOD ST	CBL 080 G013001	Status	Inspection Type Building Permit-Legalize Nonconf

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-114.3	Interior	Basemen		Furnace Room	
Violation: Maintenance of equipment.					
Notes: Oil Line in cement- Must be above in conduit					
2) 6-113.2	Interior	Basemen		Furnace Room	
Violation: Sleeping, bath or utilityrooms, cellars					
Notes: Wiring hanging free- must be tacked or bundled					
3) 6-111.3	Interior	Basemen		Furnace Room	
Violation: Water supply.					
Notes: Relief valve on water heater needs extending					
4) 6-116.5	Interior	Basemen		all	
Violation: Fire Protection					
Notes: Need working smoke detector					

Comments: