

## Air Source Heat Pump Locations

Reviewed for Code Compliance  
Inspections Division  
Approved with Conditions

Date: 10/06/15

Tom Werley  
48 Sheffield Street  
Portland, ME 04102

System Type:

Air Source Heat Pump

Drawing Name:

Site Map

Page: 1 of 1

Drawn By: L. Brostek

Date: October 1, 2015


Rev. Number: 0

Project Design Notes:

(1) Mitsubishi MSZ FH12 Interior Unit  
Rated Capacity 12,000 Btu / hr  
Mounted to wall frames  
Weight of unit is 29 lbs

(1) Mitsubishi MUJ FH12 Exterior Unit  
Rated Capacity 12,000 Btu / hr  
Installed on wall-mount bracket  
Weight of unit is 83 lbs

The Interior unit is wall-mounted in the living area, to the right of the door leading into the sunroom. The exterior unit is wall-mounted on the exterior of the same wall..



Note: Home is built of traditional wood framing and is sufficient to support the additional load of the equipment being installed.

© Copyright ReVision Energy

This diagram is provided as a service and is based on the understanding of the information supplied. It is subject to change based on actual conditions, applicable edition of the National Electric Code, and local governmental authorities.