

*City of Portland, Maine
Inspections Division
Violations Report*

Appointment Date Between 5/1/2016 And 12/16/2016

Dist. #	Sch. Date Contact:	CBL	Appl. Type Inspector	Schedule Type Comments	Appl #	Location			
	06/24/2016	080 I001001	Fire Company Christopher Flemin	FP Routine Inspection		0214-216 BRIGHTON AVE			
	Pva Limited Partnership 214 BRIGHTON AVE								
	<u>Code</u>	<u>Violation</u>		<u>Status</u>	<u>IntExt</u>	<u>Floor</u>	<u>Area</u>	<u>Corrected</u>	<u>Date</u>
	NFPA 101-7.2.4.3.1-73.10	Fire Barrier Requires Maintenance Hole in wall in basement stairwell.		Open				<input checked="" type="checkbox"/>	1/17/17
	Portland Chapter 10 Code	Knox Box Required Buildings with alarm system require knox box.		Open				<input type="checkbox"/>	
	<i>Stickers ordered for doors.</i>								
3	06/30/2016	080 I001001	Fire Company Christopher Flemin	FP Routine Inspection		7-9 ELIZABETH RD			
	PVA LIMITED								
	<u>Code</u>	<u>Violation</u>		<u>Status</u>	<u>IntExt</u>	<u>Floor</u>	<u>Area</u>	<u>Corrected</u>	<u>Date</u>
	NFPA 101-31.3.7-73.20	Floor/ Ceilings Assembly Not Smoke-tight Hole in ceiling in the basement stair of 9 Elizabeth.		Open				<input checked="" type="checkbox"/>	1/17/17
3	07/02/2016	080 I001001	Fire Company Christopher Flemin	FP Routine Inspection		226-183 Douglas St./Massach			
	PVA LIMITED								
	<u>Code</u>	<u>Violation</u>		<u>Status</u>	<u>IntExt</u>	<u>Floor</u>	<u>Area</u>	<u>Corrected</u>	<u>Date</u>
	NFPA 101-31.3.1.1.1-73.15	Vertical Openings Not Fire Rated Hole in Basement stairwell.		Open				<input checked="" type="checkbox"/>	1/17/17
	*								
3	07/02/2016	080 I001001	Fire Company Christopher Flemin	FP Routine Inspection		230-232 Douglas St.			
	PVA LIMITED								
	<u>Code</u>	<u>Violation</u>		<u>Status</u>	<u>IntExt</u>	<u>Floor</u>	<u>Area</u>	<u>Corrected</u>	<u>Date</u>
	NFPA 101-31.3.1.1.1-73.15	Vertical Openings Not Fire Rated Basement stairwell.		Open				<input checked="" type="checkbox"/>	1/17/17
3	07/02/2016	080 I001001	Fire Company Christopher Flemin	FP Routine Inspection		203 Massachusetts Ave.			
	PVA LIMITED								
	<u>Code</u>	<u>Violation</u>		<u>Status</u>	<u>IntExt</u>	<u>Floor</u>	<u>Area</u>	<u>Corrected</u>	<u>Date</u>
	Portland Fire Department	Knox Box Required Alarm system requires a knox box.		Open				<input type="checkbox"/>	
	<i>Stickers ordered for doors</i>								
3	07/02/2016	080 I001001	Fire Company Christopher Flemin	FP Routine Inspection		191 Massachusetts Ave.			
	PVA LIMITED								
	<u>Code</u>	<u>Violation</u>		<u>Status</u>	<u>IntExt</u>	<u>Floor</u>	<u>Area</u>	<u>Corrected</u>	<u>Date</u>
	Portland Fire Department	Knox Box Required		Open				<input type="checkbox"/>	
	<i>Stickers ordered for doors.</i>								

**Inspections Division
Violations Report**

Appointment Date Between 5/1/2016 And 12/16/2016

Dist. #	Sch. Date	CBL	Appl. Type	Schedule Type	Appl #	Location
	Contact:		Inspector	Comments		
3	07/02/2016	080 1001001	Fire Company Christopher Flemin	FP Routine Inspection		185 Massachusetts Ave.

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
Portland Fire Department	Knox Box Required Alarm system requires Knox Box.	Open				<input type="checkbox"/>	

Stickers ordered

3	07/02/2016	080 1001001	Fire Company Christopher Flemin	FP Routine Inspection		175 Massachusetts Ave.
---	------------	-------------	------------------------------------	-----------------------	--	------------------------

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
Portland Fire Department	Knox Box Required Alarm system requires a knox box on the building.	Open				<input type="checkbox"/>	

stickers ordered

Total Listed: 8

*City of Portland, Maine
Inspections Division
Violations Report*

Appointment Date Between 5/1/2016 And 12/16/2016

Dist. #	Sch. Date Contact:	CBL	Appl. Type Inspector	Schedule Type Comments	Appl #	Location
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		14 forest park

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
NFPA 101- 8.3.4.2- RN 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/20/17

Dist. #	Sch. Date Contact:	CBL	Appl. Type Inspector	Schedule Type Comments	Appl #	Location
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		10 DARTMOUTH ST

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
NFPA 101- 8.3.4.2- RN 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/20/17

Dist. #	Sch. Date Contact:	CBL	Appl. Type Inspector	Schedule Type Comments	Appl #	Location
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection Basement fire doors		14 DARTMOUTH ST

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
NFPA 101- 8.3.4.2- RN 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/20/17

Dist. #	Sch. Date Contact:	CBL	Appl. Type Inspector	Schedule Type Comments	Appl #	Location
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		18 DARTMOUTH ST

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
NFPA 101- 8.3.4.2- RN 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/20/17

Dist. #	Sch. Date Contact:	CBL	Appl. Type Inspector	Schedule Type Comments	Appl #	Location
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		34 DARTMOUTH ST

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
NFPA 101- 8.3.4.2- RN 37	60 Minute Fire Door Required Bsaeement fire doors	Open				<input checked="" type="checkbox"/>	1/23/17

Dist. #	Sch. Date Contact:	CBL	Appl. Type Inspector	Schedule Type Comments	Appl #	Location
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		196 Baxter boulevard

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
NFPA 101- 8.3.4.2- RN 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/20/17

City of Portland, Maine
Inspections Division
Violations Report

Appointment Date Between 5/1/2016 And 12/16/2016

Dist. #	Sch. Date Contact:	CBL	Appl. Type Inspector	Schedule Type Comments	Appl #	Location								
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		246 Baxter boulevard								
							Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
							NFPA 101- 8.3.4.2- rn 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/20/17
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		2 Forest park								
							Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
							NFPA 101- 8.3.4.2- rn 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/23/17
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		4 Forest park								
							Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
							NFPA 101- 8.3.4.2- rn 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/23/17
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		8 Forest park								
							Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
							NFPA 101- 8.3.4.2- rn 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/23/17
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection Fire door in basement should be replaced.		06 DARTMOUTH ST								
							Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
							NFPA 101- 8.3.4.2- rn 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/23/17
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		12 Forest park								
							Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
							NFPA 101- 8.3.4.2- rn 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/23/17

*City of Portland, Maine
Inspections Division
Violations Report*

Appointment Date Between 5/1/2016 And 12/16/2016

Dist. #	Sch. Date Contact:	CBL	Appl. Type Inspector	Schedule Type Comments	Appl #	Location
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		32 Forest park

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
NFPA 101-8.3.4.2-80 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/24/17

1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		16 Forest park
---	---------------------------	-------------	-------------------------------	-----------------------	--	----------------

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
NFPA 101-8.3.4.2-80 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/24/17

1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		18 Forest park
---	---------------------------	-------------	-------------------------------	-----------------------	--	----------------

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
NFPA 101-8.3.4.2-80 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/24/17

1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		20 Forest park
---	---------------------------	-------------	-------------------------------	-----------------------	--	----------------

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
NFPA 101-8.3.4.2-80 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/24/17

1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		22 Forest park
---	---------------------------	-------------	-------------------------------	-----------------------	--	----------------

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
NFPA 101-8.3.4.2-80 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/24/17

1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		34 DARTMOUTH ST
---	---------------------------	-------------	-------------------------------	-----------------------	--	-----------------

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
NFPA 101-8.3.4.2-80 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/23/17

*City of Portland, Maine
Inspections Division
Violations Report*

Appointment Date Between 5/1/2016 And 12/16/2016

Dist. #	Sch. Date Contact:	CBL	Appl. Type Inspector	Schedule Type Comments	Appl #	Location								
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		24 Forest park								
							Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
							NFPA 101- 8.3.4.2- RN 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/24/17
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		26 Forest park								
							Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
							NFPA 101- 8.3.4.2- RN 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/24/17
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		28 Forest park								
							Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
							NFPA 101- 8.3.4.2- RN 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/24/17
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		30 Forest park								
							Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
							NFPA 101- 8.3.4.2- RN 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/24/17
1	06/22/2016 PVA LIMITED	111 A013001	Fire Company Alan Bouchard	FP Routine Inspection		10 Forest park								
							Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
							NFPA 101- 8.3.4.2- RN 37	60 Minute Fire Door Required Basement fire doors	Open				<input checked="" type="checkbox"/>	1/20/17

Total Listed: 23