Portland, Maine



Yes. Life's good here.

September 2, 2015

FORTY NINE LLC

104 GRANT ST

PORTLAND, ME 04102

CBL: 081 A010001

Located at 202 DARTMOUTH ST

NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at the address referenced above revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at www.portlandmaine.gov.

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

Portland Fire Department

Fire Prevention Bureau

CITY OF PORTLAND PORTLAND FIRE DEPARTMENT

380 Congress Street Portland, Maine 04101

Inspection Violations

Owner/Manager FORTY NINE LLC				Inspector Christopher Goodall		Inspection Date 9/1/2015	
Location 202 DARTMOUTH ST		CBL 081 A010001		Status Failed		Inspection Type	
						Fire Company-FP Routine Inspec	
Code	İ	nt/Ext	Floor	Unit No.	Area	Compliance Date	
1) 69.05 Violation:	PORTLAND FIRE DEPARTMENT CHAPTER 10 4.3.1, 4.3.2 BUILDING ADDRESS NOT MARKED ON BUILDING; 4.3.1 Signs shall be located in a position readily visible as approaching from the main access and approved by the Fire Department. Signs shall be illuminated or retro reflective on a						
	Ť	d by the Fire Department. e building and building sign as approved					
Notes:	NO NUMBER ON STREET SIDE						
2) 73.20							
Violation:	NFPA 101- 31.3.7 FLOOR/ CEILINGS ASSEMBLY NOT SMOKE-TIGHT; IN BUILDINGS OTHER THAN THOSE MEETING THE REQUIREMENTS OF 31.3.7.1, 31.3.7.2, 31.3.7.3, 31.3.7.4, OR 31.3.7.5, IN ADDITION TO THE FOLLOWING CRITERIA TO BE MET.						
Notes:	PLASTER ON WALLS IN REAR STAIRWELL NEEDS REPAIR - AREAS MISSING, LATH EXPOSED						
3) 81.20							
Violation:	conducted, re	ecords fo	r manual ir	spections sh	all be kept on a t	Where manual inspections are ag or label attached to the fire by an electronic method.	

EXTINGUISHERS OUT OF DATE - NEED SERVICING

Comments:

Notes:

STATE OF MAINE

DISTRICT COURT Location: Portland Docket No.

CITY OF PORTLAND and body politic and Corporate, located in the County of Cumberland and State of Maine,

Plantiff,

FIRE PREVENTION AND PROTECTION CODE VIOLATION

(M.R. CIV. P. 80H AND 80k)

v.

Forty Nine LLC Defendant

SUMMONS NUMBER:

354857

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 11/09/2015. I strongly urge you to contact Victoria Meserve at Fire Prevention at (207)-874-8400 or via e-mail at meservev@portlandmaine.gov to set up an inperson meeting to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 11/09/2015.

Dated: 9/10/15

Adam R. Lee, Esq. Bar No. 4143 Associate Corporation Council

City of Portland 389 Congress St Portland, ME 04101 207-874-8480