Inspections Division
Date: 04/27/16

NOTES:

- PORCH ROOF TO be SUPPORTED DURING DEMO & CONSTRUCTION
- ALL FRAMING to be Pressure treated
- EXISTING 8" SONOTUBE cement Filled POST to be INSPECTED for depth - Replaced if NOT 4' below grade
- SIMPSON STRONG TIE CONNECTORS (see PDF)
- COMPOSITE RAILING PER CODE