

ELECTRICAL PERMIT

City of Portland, Maine

To the Electrical Inspector, Portland Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland's Electrical Ordinances, National Electrical Code and the following specifications: 28



Date: 5/28/15

Permit #: 2015 01196

CBL#: 083A AD05

ADDRESS: Meadow Ave Great Diamond Island METER MAKE/MODEL #: 100 Amp overhead

CMP Work Order #: 1030012005 OWNER: John Barron Dorris

TENANT: _____ PHONE #: (410)960-7050

PLEASE HAVE YOUR PERMIT # (OR JOB ID) READY & CALL 874-8703 TO SCHEDULE AN INSPECTION!

| | | | | | | TOTAL EACH FEE | |
|--------------------|-------------------------------------|--------------------|-------------------------------------|---------------|-------------------------------------|-----------------|-------|
| OUTLETS: | | Receptacles | | Switches | | Smoke Detector | 0.20 |
| FIXTURES: | | Incandescent | | Flourescent | | Strips | 0.20 |
| SERVICES: | <input checked="" type="checkbox"/> | Overhead | <input type="checkbox"/> | Underground | <input type="checkbox"/> | TTL Amps <800 | 15.00 |
| | | | | | <input type="checkbox"/> | TTL Amps >800 | 25.00 |
| TEMPORARY SERVICE: | | Overhead | <input checked="" type="checkbox"/> | Underground | | TTL Amps | 25.00 |
| METERS: | 1 | (Number of) | | | | | 1.00 |
| MOTORS: | | (Number of) | | | | | 2.00 |
| RESID/COMMER: | | Electric Units | | | | | 1.00 |
| HEATING: | | Oil/Gas Units | <input type="checkbox"/> | Interior | <input type="checkbox"/> | Exterior | 5.00 |
| APPLIANCES: | | Ranges | | Cook Tops | | Wall Ovens | 2.00 |
| | | Insta-hot | | Water Heaters | | Fans | 2.00 |
| | | Dryers | | Disposals | | Dishwasher | 2.00 |
| | | Compactors | | Spa | | Washing Machine | 2.00 |
| | | Others (denote) | | | | | 2.00 |
| MISC. (# of): | | Air Cond (Window) | | | | | 3.00 |
| | | Air Cond (Central) | | | | Pools | 10.00 |
| | | HVAC | | EMS | | Thermostat | 5.00 |
| | | Signs | | | | | 10.00 |
| | | Alarms/Resident | | | | | 5.00 |
| | | Alarms/Commer | | | | | 15.00 |
| | | Heavy Duty (CRKT) | | | | | 2.00 |
| | | Alterations | | | | | 5.00 |
| | | Fire Repairs | | | | | 15.00 |
| | | Emergency Lights | | | | | 1.00 |
| | | Emer Generators | | | | | 20.00 |
| | | Circus/Carnival | | | | | 25.00 |
| PANELS: | <input checked="" type="checkbox"/> | Service | <input type="checkbox"/> | Remote | <input checked="" type="checkbox"/> | Main | 4.00 |
| TRANSFORMER: | <input type="checkbox"/> | 0-25 Kva | | | | | 5.00 |
| | <input type="checkbox"/> | 25-200 Kva | | | | | 8.00 |
| | <input type="checkbox"/> | Over 200 Kva | | | | | 10.00 |

RECEIVED
MAY 28 2015
 Dept. of Building Inspections
 City of Portland Maine

MINIMUM COMMERCIAL FEE: \$55.00 **MINIMUM RESIDENTIAL FEE: \$45.00**
 Brief Description of work: _____ **TOTAL DUE: 45.00**

34 Back

PLEASE HAVE YOUR PERMIT # (OR JOB ID) READY & CALL 874-8703 TO SCHEDULE AN INSPECTION!

CONTRACTOR INFORMATION:

Contractor Name: Michael Mooney Master License #: ms60003472
 Address: 29 Stockman Ave Saco, Me 04072 Limited License #: _____
 Telephone & E Mail: 284-8817 mwm207@gmail.com

Contractor Signature: Michael Mooney

PLEASE HAVE YOUR PERMIT # (OR JOB ID) READY & CALL 874-8703 TO SCHEDULE AN INSPECTION!

Note on Back

CBL:

I only replaced line & load cables
and a new meter socket as the
old meter socket was burning up. It
has a fully new 100 Amp S.D. panel.
I also added another ground rod and
moved the attachment location to be
away from window. CMP has
all ready reconnected power to existing
point of attachment, but it needs to be
moved. Any questions call Mike Meoney
@ 284-8817