

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: Waymouth St C.D.I.		Owner: Jerry & Mary Jean Crouter		Phone:		Permit No: 990222	
Owner Address: 51 Melrose St Portland		Lessee/Buyer's Name:		Phone:		BusinessName:	
Contractor Name: Stephen Berube		Address: 28 Vail St Portland ME 04103		Phone: 772-2541 / 766-0044 (site)		<div style="border: 2px solid black; padding: 5px; text-align: center;"> PERMIT ISSUED Permit Issued: MAR 17 1999 CITY OF PORTLAND </div>	
Past Use: 1-family		Proposed Use: Same		COST OF WORK: \$ 20,000 PERMIT FEE: \$ 130.00		INSPECTION: Use Group: Type:	
Proposed Project Description: Construct deck & sunporch interior renovatons		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/>		Signature: _____ Date: _____		Zone: CBL: 083a-L-005 IR-2 Zoning Approval:	
Permit Taken By: SP (via mail)		Date Applied For: March 11, 1999		Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>		Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied	

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

PERMIT ISSUED WITH REQUIREMENTS

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT		ADDRESS:		DATE: March 11, 1999		PHONE:	
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE						PHONE:	

CEO DISTRICT

COMMENTS

3/30/99 Discuss project with Steve Berube - Foundation posts, posts, beams, stairways, guardrails & handrails, Framing all o.k. DC

6/17/99 Final w/ Steve Berube require code compliant steps to 1st floor bedroom, Replace exterior entry steps, install chimney fire cap DC
OK 8/5/99 DC

Inspection Record

Type

Foundation: _____
Framing: _____
Plumbing: _____
Final: _____
Other: _____

Date
3/30 DC
3/30 DC

Applicant: Stephen Bernabe

Date: 3/15/99

Address: Weymouth St G.D.I

C-B-L: 03A-L-54/b

CHECK-LIST AGAINST ZONING ORDINANCE

Date - Existing 1989 -

Zone Location - IR-2

Interior or corner lot - Spring St

Proposed Use/Work -

Sewage Disposal -

Lot Street Frontage -

Front Yard - 25' req N/A

Rear Yard - 25' req - 36' shown

Side Yard - 20' req - 147' shown

Projections -

Width of Lot -

Height - 1 story addition

Lot Area - 20,000^{sq} req 22,936^{sq} shown

Lot Coverage/ Impervious Surface -

Area per Family -

Off-street Parking -

Loading Bays -

Site Plan -

Shoreland Zoning/ Stream Protection - N/A


Flood Plains - Zone C

PLOT PLAN

Existing Structure

83A - L - 5+6

Great Diamond Island



Weymouth St

North

Revised per contractor
2/15/99

Structure is a recently built 2 story wood frame, with no interior finish, and minimal plumbing and electrical. Plan is to finish off the first floor; installing bath, kitchen, closets, and pantry. Complete the electrical and plumbing for the first floor, insulate, sheetrock, + trim.

Additional interior work includes creating a 4' opening in existing 2x6 wall marked (A) on drawing using a 6x6 header made from 3, 2x6's @ 1/2" plywood, removing existing wall marked (B) and replacing with a 6x10 beam 12' 10" long made from 3 2x10's @ 1/2 plywood, Replacing window marked (C) with a 2'-8", 6'-8" door @ a 6x6 header (3-2x6's @ 1/2 ply), to go out onto screened in porch. Building closets in area marked (D) and (E) and a pantry in area marked (F). This will be 2x4 construction @ 16" centers.

Exterior: Build deck and screened in porch as drawn @ 2x8 joists 16" centers, 5/4x6 decking, double 2x8's on outside edge @ 4x6 posts on 4' deep tapered concrete piers @ drift pins. Piers to be placed ~~every~~ ^{as drawn} 7 feet. Deck to have a 2x6 rail 3' high @ 2x2 spindles 4" on center. Screened in porch walls to be 4x4's every 4 feet @ a 4x6 beam overhead and 3' high solid rail. Roof to have 2x6 rafters 16" on center and 1x6 roof boards. Exposed ceiling joist 4x6 on 4' centers

THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED

**Building or Use Permit Pre-Application
Additions/Alterations/Accessory Structures
To Detached Single Family Dwelling**

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

NOTEIf you or the property owner owes real estate or personal property taxes or user charges on any property within the City, payment arrangements must be made before permits of any kind are accepted.**

Location/Address of Construction: <i>Weymouth St Great Diamond Island</i>			
Tax Assessor's Chart, Block & Lot Number Chart# <i>83A</i> Block# <i>L</i> Lot# <i>5+6</i>		Owner: <i>Jerry + Mary Jean Creuter</i> Telephone#:	
Owner's Address: <i>51 Melrose St Portland</i>		Lessee/Buyer's Name (If Applicable)	Cost Of Work: <i>\$22,000.00</i> Fee: <i>\$130.00</i>
Proposed Project Description:(Please be as specific as possible) <i>Build 12'x 22' porch, 14'x 12' sunporch, finish off 1st floor (elect, plumb subcontract) remove 12' interior wall, add beam, add + change windows, build bath walls + closets</i>			
Contractor's Name, Address & Telephone <i>Stephen Berube 28 Vaill St. Portland Me (772-2541)</i>		JOB SITE (766-0044) Rec'd By:	

Separate permits are required for Internal & External Plumbing, HVAC and Electrical installation.

- All construction must be conducted in compliance with the 1996 B.O.C.A. Building Code as amended by Section 6-Art II.
- All plumbing must be conducted in compliance with the State of Maine Plumbing Code.
- All Electrical Installation must comply with the 1996 National Electrical Code as amended by Section 6-Art III.
- HVAC(Heating, Ventilation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code.

You must Include the following with you application:

- 1) A Copy of Your Deed or Purchase and Sale Agreement
- 2) A Copy of your Construction Contract, if available
- 3) A Plot Plan (Sample Attached)

If there is expansion to the structure, a complete plot plan (Site Plan) must include:

- The shape and dimension of the lot, all existing buildings (if any), the proposed structure and the distance from the actual property lines. Structures include decks porches, a bow windows cantilever sections and roof overhangs, as well as, sheds, pools, garages and any other accessory structures.
- Scale and required zoning district setbacks

4) Building Plans (Sample Attached)

A complete set of construction drawings showing all of the following elements of construction:

- Cross Sections w/Framing details (including porches, decks w/ railings, and accessory structures)
- Floor Plans & Elevations
- Window and door schedules
- Foundation plans with required drainage and dampproofing
- Electrical and plumbing layout. Mechanical drawings for any specialized equipment such as furnaces, chimneys, gas equipment, HVAC equipment (air handling) or other types of work that may require special review must be included.

Certification

I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant: <i>Stephen Berube</i>	Date: <i>March 8, 1999</i>
---	----------------------------

Building Permit Fee: \$25.00 for the 1st \$1000.cost plus \$5.00 per \$1,000.00 construction cost thereafter.

BUILDING PERMIT REPORT

DATE: 13 March 1999 ADDRESS: Weymouth St. G.D.I. CBL 083A-L-005
REASON FOR PERMIT: To Construct deck & sun porch.
BUILDING OWNER: J. M. J. Crowter
CONTRACTOR: Stephen Berube.
PERMIT APPLICANT: ↑
USE GROUP R-3 BOCA 1996 CONSTRUCTION TYPE 513

CONDITION(S) OF APPROVAL


This Permit is being issued with the understanding that the following conditions are met:

Approved with the following conditions: *1, *2, *2.6, *3, *8, *10, *26, *31, *32


1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
2. Before concrete for foundation is placed, approvals from ~~the Development Review Coordinator~~ and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
- 2.5 Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the floor, and that the top of the drain is not less than 6 inches above the top of the footing. The top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforated pipe is used, the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforations shall be protected with an approved filter membrane material. The pipe or tile shall be placed on not less than 2" of gravel or crushed stone, and shall be covered with not less than 6" of the same material. Section 1813.5.2
- 2.6 Foundations anchors shall be a minimum of 1/2" in diameter, 7" into the foundation wall, minimum of 12" from corners of foundation and a maximum 6' o.c. between bolts. (Section 2305.17) piers on footing - anchored - wood Framing
3. Precaution must be taken to protect concrete from freezing. Section 1908.0 Fastened To piers -
4. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
5. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of 1/2 inch gypsum board or the equivalent applied to the garage means of 1/2 inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
6. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993). Chapter 12 & NFPA 211
7. Sound transmission control in residential building shall be done in accordance with Chapter 12 section 1214.0 of the city's building code.
8. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. (Handrails shall be a minimum of 34" but not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".) Handrail grip size shall have a circular cross section with an outside diameter of at least 1 1/4" and not greater than 2". (Sections 1021 & 1022.0) - Handrails shall be on both sides of stairway. (Section 1014.7)
9. Headroom in habitable space is a minimum of 7'6". (Section 1204.0)
10. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum 11" tread. 7" maximum rise. (Section 1014.0)
11. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6' 8") 1014.4

knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft. (Section 1018.6)

13. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units. Section 1010.1
14. All vertical openings shall be enclosed with construction having a fire rating of at least one (1)hour, including fire doors with self closer's. (Over 3 stories in height requirements for fire rating is two (2) hours.) Section 710.0
15. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment. Table 302.1.1
16. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms
 - In each story within a dwelling unit, including basementsIn addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required) Section 920.3.2
17. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. Section 921.0
18. The Fire Alarm System shall be maintained to NFPA #72 Standard.
19. The Sprinkler System shall maintained to NFPA #13 Standard.
20. All exit signs, lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023. & 1024. Of the City's building code. (The BOCA National Building Code/1996)
21. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
22. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
23. Ventilation shall meet the requirements of Chapter 12 Sections 1210. Of the City's Building Code. (crawl spaces & attics)
24. All electrical, plumbing and HVAC permits must be obtained by a Master Licensed holders of their trade. No closing in of walls until all electrical (min. 72 hours notice) and plumbing inspections have been done.
25. All requirements must be met before a final Certificate of Occupancy is issued.
- X26. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code. (The BOCA National Building Code/1996).
27. Ventilation of spaces within a building shall be done in accordance with the City's Mechanical Code (The BOCA National Mechanical Code/1993). (Chapter M-16)
28. Please read and implement the attached Land Use-Zoning report requirements. *to remain 1/4 in.*
29. Boring, cutting and notching shall be done in accordance with Sections 2305.4.4, 2305.5.1 and 2305.3. of the City's building code.
30. Glass and glazing shall meet the requirements of Chapter 24 of the building code.
- X31. Bracing may be required on columns -
- X32. All Support columns must have full bearing to Foundation.
33. _____


P. Samuel Hoffses, Building Inspector

cc: Lt. McDougall, PFD
Marge Schmuckal, Zoning Administrator




PROPOSED LEFT ELEVATION

PLAN

4' COULD BE ADDED OFF LIVING ROOM IF DESIRED.


SY
SCALE
DATE
MA



EXISTING

EXISTING ROOF
CIRCULAR

FRONT DOOR 4' OUT OF GRADE



EXISTING
8' CB