

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Maine Department of Human Services
Division of Health Engineering, Station 10 SHS
(207) 287-5672 FAX (207) 287-4172

Town, City, Plantation
PORTLAND, GREAT DIAMOND ISLAND



Street, Road Subdivision
82 WEYMOUTH STREET

Owner's Name
PETER BOGDANOVICH

SITE PLAN

Scale 1" = 50 Ft.
or as shown

SITE LOCATION PLAN
(Attach Map from Maine Atlas for New System Variance)



APPROXIMATE EXISTING DISPOSAL AREA

PROPOSED DISPOSAL AREA

NOTE: PROPERTY LINES PER TOWN TAX MAP AND AS POINTED OUT BY OWNER'S REPRESENTATIVE ON-SITE. VERIFY PRIOR TO INSTALLATION TO ASSURE ALL PORTIONS OF DISPOSAL AREA ARE CONTAINED ON PROPERTY

SOIL DESCRIPTION AND CLASSIFICATION (Location of Observation Holes Shown Above)

Observation Hole TP 1 Test Pit Boring
" Depth of Organic Horizon Above Mineral Soil

DEPTH BELOW MINERAL SOIL SURFACE (inches)	Texture	Consistency	Color	Mottling
0	SANDY		BROWN	
0-10	LOAM			
10-20		FRIABLE		
20-30	LOAMY SAND		YELLOWISH BROWN	
30-35				
35-40	BEDROCK			
40-50				

Soil Classification 2 A	Slope 0-3%	Limiting Factor 33"	<input type="checkbox"/> Ground Water <input type="checkbox"/> Restrictive Layer <input checked="" type="checkbox"/> Bedrock <input type="checkbox"/> Pit Depth
Profile	Condition		

Observation Hole _____ Test Pit Boring
" Depth of Organic Horizon Above Mineral Soil

DEPTH BELOW MINERAL SOIL SURFACE (inches)	Texture	Consistency	Color	Mottling
0				
10				
20				
30				
40				
50				

Soil Classification	Slope	Limiting Factor	<input type="checkbox"/> Ground Water <input type="checkbox"/> Restrictive Layer <input type="checkbox"/> Bedrock <input type="checkbox"/> Pit Depth
Profile	Condition		

Albert Frick
Site Evaluator Signature

163
SE #

7/14/2014
Date