

. . . Fire Protection by Computer Design

Residential Fire Protection
64 Daggett Hill Rd.
Greene, ME 04236
946-3473

Job Name : LUEDKE RESIDENCE
Building : WOOD STRUCTURE
Location : 2ND FLR HOUSE
System : 1
Contract : 17010
Data File : LUEDKE RESIDENCE-2ND FLR HOUSE.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - LUEDKE RESIDENCE Date - 4/11/2017
Location - 2ND FLR HOUSE
Building - WOOD STRUCTURE System No. - 1
Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - 17010
Calculated By - T. PRAY Drawing No. - 1 OF 1
Construction: (X) Combustible () Non-Combustible Ceiling Height 8'-0"
OCCUPANCY - RESIDENTIAL

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 7 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make VIKING Model VK486
I Elevation at Highest Outlet - 119.34Feet Size 7/16" K-Factor 4.0
G Note: Temperature Rating
N

Calculation Gpm Required 26.05 Psi Required 75.27 At Test
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 4/15/2015 Rated Cap. Cap.
T Time of Test - N/A @ Psi Elev.
E Static (Psi) - 105 Elev.
R Residual (Psi) - 20 Other Well
Flow (Gpm) - 1200 Proof Flow Gpm
S Elevation - 100.0'

P Location: HYDRANTS ARE LOCATED ON CRESCENT AVE., SEE PLOT PLAN

L Source of Information: PORTLAND WATER DISTRICT
Y

Water Supply Curve (C)

Residential Fire Protection
LUEDKE RESIDENCE


Page 2
Date 4/11/2017

City Water Supply:

C1 - Static Pressure : 105
C2 - Residual Pressure: 20
C2 - Residual Flow : 1233

Demand:

D1 - Elevation : 8.376
D2 - System Flow : 26.0461
D2 - System Pressure : 75.273
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 26.0461
Safety Margin : 29.660



Fittings Used Summary

Residential Fire Protection
LUEDKE RESIDENCE

Page 3
Date 4/11/2017

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
N	CPVC 90'Elb Harvel-Spears	7	7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

Pressure / Flow Summary - STANDARD

Residential Fire Protection
LUEDKE RESIDENCE

Page 4
Date 4/11/2017

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
3	119.34	4	10.6	na	13.02	0.0508	256	10.6
4	119.34	4	10.6	na	13.02	0.0508	256	10.6
53	118.92		11.57	na				
54	110.58		42.77	na				
55	99.54		51.54	na				
TOR	99.54		56.22	na				
BOR	92.375		69.93	na				
TEST	100.0		75.27	na				

The maximum velocity is 13.93 and it occurs in the pipe between nodes 53 and 54

Final Calculations - Hazen-Williams

Residential Fire Protection
LUEDKE RESIDENCE

Page 5
Date 4/11/2017

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
3 to 53	13.02 13.02	0.874 150 0.0947	1T	8.053 0.0 0.0	0.250 8.052 8.302	10.600 0.182 0.786			K Factor = 4.00	
	0.0 13.02						11.568		K Factor = 3.83	
4 to 53	13.02 13.02	0.874 150 0.0947	1T	8.053 0.0 0.0	0.250 8.052 8.302	10.600 0.182 0.786			K Factor = 4.00	
53 to 54	13.03 26.05	0.874 150 0.3415	3N 1O	21.0 3.0 0.0	56.800 24.000 80.800	11.568 3.612 27.590			Vel = 13.93	
54 to 55	0.0 26.05	1.101 150 0.1109	1N 2O	7.0 10.0 0.0	19.010 17.000 36.010	42.770 4.781 3.994			Vel = 8.78	
55 to TOR	0.0 26.05	1.101 120 0.1676	2O	10.0 0.0 0.0	17.880 10.000 27.880	51.545 0.0 4.673			Vel = 8.78	
TOR to BOR	0.0 26.05	1.049 150 0.1404	2E 1Z	6.044 3.022 0.0	9.500 9.066 18.566	56.218 11.103 2.606			* Fixed loss = 8 Vel = 9.67	
BOR to TEST	0.0 26.05	1.314 150 0.0469	1T	4.495 0.0 0.0	180.000 4.495 184.495	69.927 -3.302 8.648			Vel = 6.16	
	0.0 26.05						75.273		K Factor = 3.00	