SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Maine Department of Human Services
Division of Health Engineering, Station 10 SHS
(207) 287-5672 FAX (207) 287-4172

Town, City, Plantation	Street, Road, Subdivision	Owner's Name
PORTLAND	GREAT DIAMOND ISLAND	LISA BOWMAN

FILL REQUIREMENTS

Depth of Fill (Upslope) : 9" – 11"
Depth of Fill (Downslope) : 7" – 12"
DEPTHS AT CROSS-SECTION (shown below)

CONSTRUCTION ELEVATIONS

Finished Grade Elevation
Top of Distribution Pipe or Proprietary Device
Bottom of Disposal Area

SEE DETAIL BELOW

ELEVATION REFERENCE POINT

Location & Description TOP OF LOWEST STEP ON PORCH, 9" ABOVE GRADE
Reference Elevation is: 0.0" or _____

SCALE:
VERTICAL: 1" - 5 FT
HORIZONTAL: 1" - 10 FT

DISPOSAL AREA CROSS SECTION

SEE ELJEN IN-DRAIN MANUAL ON SERIAL DISTRIBUTION ON SLOPES FOR PROPER PIPING

	ROW 1	2
	-70"	-80"
	-80"	-90"
	-84"	-94"
	-91"	-101"
	-97"	-106"

CAP TOE OF FILL WITH SANDY LOAM MATERIAL TO PREVENT WASTEWATER BREAKOUT

Albert Frick — Site Evaluator Signature
163 — SE #
3/3/2015 — Date
Page HHE-2

ALBERT FRICK ASSOCIATES – 95A COUNTY ROAD ROAD GORHAM, MAINE 04038 – (207) 839-5563

CITY OF PORTLAND, MAINE — RESURGAM

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/15/15