

### ROOF FRAMING PLAN


1/4" = 1'-0"

#### PLAN NOTES:

1. REFER TO ARCH FOR T/ WALL PLATE ELEVATIONS.
2. ■ INDICATES WOOD STUD BEARING WALLS
3. EXTERIOR WALLS SHALL BE 2x6 AT 16" OC, U.N.O.
4. Hx INDICATES HEADER MARK. SEE SCHEDULE THIS SHEET
5. ALL EXTERIOR WALLS SHALL BE CONSIDERED SHEAR WALLS. WALLS SHALL BE SHEATHED WITH 15/32" APA RATED SHEATHING NAILED w/ 0.131" x 2 1/2" LONG NAILS AT 4" OC AT ALL PANEL EDGES AND AT 12" OC AT INTERMEDIATE SUPPORTS. HORIZONTAL BLOCKING IS REQUIRED AT ALL PANEL EDGES, U.N.O.

HEADER SCHEDULE			
PLAN MARK	HEADER SIZE	JACK STUDS EA. END (U.N.O.)	KING STUDS EA. END (U.N.O.)
H1	(2) 2x6	(1) 2x6	(1) 2x6
H2	(2) 2x8	(2) 2x6	(2) 2x6
H3	(3) 2x8	(2) 2x6	(2) 2x6
H4	(3) 2x10	(2) 2x6	(2) 2x6
H5	(2) 1 3/4" x 9 1/2" LVL	(2) 2x6	(2) 2x6

NOTES:  
1. SEE DETAIL 2/S8 FOR TYPICAL HEADER DETAIL



Stamp

Revisions:	No:	Date:	Description:



23 Thornbury Way  
Windham, ME 04062  
(207) 892-0983  
info@m2se.com

Client: AMY FARRELL

Sheet Title: ROOF FRAMING PLAN

Project Name: FARRELL RESIDENCE

GREAT DIAMOND ISLAND,  
PORTLAND, MAINE

Project No: 17079  
Designed By: MJM  
Drawn By: MJM  
Checked By: MJM  
Scale: AS NOTED  
Date: 09/25/2017

S5