This drawing is an instrument of professional service, and shall not be used, in whole or in part, for any project other than for which it was created without the express, written consent of M² Structural Engineering, P.C. Any unauthorized use, reuse, modification or alteration, including automated conversion of this document shall be at the user's sole risk without liability or legal exposure to M² Structural Engineering, P.C.

HEADER SCHEDULE

PLAN MARK	HEADER SIZE	JACK STUDS EA. END (U.N.O)	KING ST EA. END (U
H1	(2) 2x6	(1) 2x6	(1) 2x
H2	(2) 2x8	(2) 2x6	(2) 2x
H3	(3) 2x8	(2) 2x6	(2) 2x
H4	(3) 2x10	(2) 2x6	(2) 2xo
H5	(2) 1¾"x9½" LVL	(2) 2x6	(2) 2x6

NOTES:
1. SEE DETAIL 2/S8 FOR TYPICAL HEADER DETAIL

ROOF FRAMING PLAN

1/4" = 1'-0"

PLAN NOTES:

1. REFER TO ARCH FOR T/ WALL PLATE ELEVATIONS.
2. ▬ INDICATES WOOD STUD BEARING WALLS
3. EXTERIOR WALLS SHALL BE 2x6 AT 16" oc, TYP., U.N.O.
4. Hx INDICATES HEADER MARK. SEE SCHEDULE THIS SHEET
5. ALL EXTERIOR WALLS SHALL BE CONSIDERED SHEAR WALLS. WALLS SHALL BE SHEATHED WITH 15/32" APA RATED SHEATHING NAILED w/ 0.131"ø x 2½" LONG NAILS AT 4" oc AT ALL PANELS EDGES AND AT 12" oc AT INTERMEDIATE SUPPORTS. HORIZONTAL BLOCKING IS REQURIED AT ALL PANEL EDGES, U.N.O.

CITY OF PORTLAND, MAINE — RESURGAM

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 12/11/17

Revisions:		
No:	Date:	Description:

M² STRUCTURAL ENGINEERING, P.C.
23 Thornbury Way
Windham, ME 04062
(207) 892-0983
info@m2se.com

Client: AMY FARRELL

Sheet Title: ROOF FRAMING PLAN

Project Name: FARRELL RESIDENCE
GREAT DIAMOND ISLAND,
PORTLAND, MAINE

Project No:	17079
Designed By:	MJM
Drawn By:	MJM
Checked By:	MJM
Scale:	AS NOTED
Date:	09/25/2017

S5