SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Department of Health & I
Division of Environm
(207) 287-5672 Fax: (

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date:

Town, City, Plantation	Street, Road, Subdivision	Owner's N
Portland	233 Woodside Dr.	Oliver Tenn

SUBSURFACE WASTEWATER DISPOSAL PLAN

0

SCALE: 1" = 20 FT.

Elev	Fill
C- 39"	31"
D- 45"	37"
E- 64"	56"
F- -58	50"

FILL REQUIREMENTS		CONSTRUCTION ELEVATIONS		ELEVATION REFERENCE POINT
Depth of Fill (Upslope)	31"	Finished Grade Elevation	-08"	Location & Description: 17" Beech Tree with a nail 29" above the
Depth of Fill (Downslope)	37"	Top of Distribution Pipe or Proprietary Device	-14"	Reference Elevation: Ground @ Elev 0"
		Bottom of Disposal Area	-33"	

DISPOSAL AREA CROSS SECTION

Scale
Horizontal 1" = 4 ft.
Vertical 1" = 4 ft.

Note: Scarify soil surface and mix fill 6" deep with the original soil - Transitional Horizon
6" Clean 1 1/2" crushed stone beneath the chambers, 18" around them.

Kenneth Gruder — 73 — 3-24-17

Site Evaluator Signature — SE # — Date