



BASEMENT

- LEGEND**
- ▷ 155F RES 1/2" WHITE SIDEWALL
 - 155F OR 1/2 BRASS PENDENT
 - 155F OR 1/2 BRASS UPRIGHT
 - ⊗ 155F RES 1/2" WHITE RECESSED PENDENT
 - ⊕ 155F OR 1/2" WHITE RECESSED PENDENT
 - HANGER
 - RISE OR DROP NIPPLE
 - VICTAULIC COUPLING

- GENERAL NOTES**
- FF K=XX FIN FLR TO CENTERLINE OF PIPE
 - C K=XX CEILING TO CENTERLINE OF PIPE
 - TJ K=TOP OF JOIST TO CENTERLINE OF PIPE
 - BJ K=BOTTOM OF JOIST TO CENTERLINE OF PIPE
 - BB K=BOTTOM OF BEAM TO CENTERLINE OF PIPE
 - ELEV K=CIVIL ELEVATION OF CENTERLINE OF PIPE

- GENERAL NOTES**
- ALL DIMENSIONS ARE CENTER TO CENTER U/N
 - ALL THREADED PIPE TO BE SCH. 40 BLACK STEEL
 - ALL SCREWED FITTINGS TO BE STD. WIT. C.I. BLACK U/N
 - ALL GROOVED PIPE TO BE SCH. 10 BLACK STEEL
 - ALL OTHER PIPING TO BE CPVC PLASTIC
 - ALL OTHER FITTINGS TO BE CPVC PLASTIC
 - DRY SYSTEM CAPACITY IS 343 GALLONS

- SYSTEM DESIGN**
- 10 VIKING WK302 OR BRASS PENDENTS 1/2"x1/2" K=5.6
 - 7 VIKING WK300 OR BRASS UPRIGHTS 1/2"x1/2" K=5.6
 - ⊕ 58 VIKING WK302 WHITE OR RECESSED PENDENTS 1/2"x1/2" K=5.6
 - ⊗ 66 VIKING WK456 RESIDENTIAL CONGEALED PENDENTS 1/2"x1/2" K=4.9

REVISION

NO.	DATE	DESCRIPTION
1	07-10-14	TITLE
2	07-11-14	BRKAW BY JAL
3	07-14-14	APPROVED BY SJC
4	1-10-17	SCALE 1/8" = 1'-0" U/N

PROJECT INFORMATION

INN AT DIAMOND COVE
 MCKINLEY COURT
 GREAT DIAMOND ISLAND
 PORTLAND, MAINE

DATE: 07-10-14
 DRAWN BY: JAL
 CHECKED BY: SJC
 SCALE: 1/8" = 1'-0" U/N