



- 9 VIKING WK300
OR BRASS UPRIGHTS
1/2"x1/2" K=5.6
- 63 VIKING WK302
WHITE OR RECESSED PENDENTS
1/2"x1/2" K=5.6
- 66 VIKING WK456
RESIDENTIAL CONCEALED PENDENTS
1/2"x1/2" K=4.9

LEGEND

- ▷ 155F OR 1/2" WHITE SIDEWALL
- 155F 1/2 BRASS PENDENT
- 155F 1/2 BRASS UPRIGHT
- ⊗ 155T OR 1/2" WHITE RECESSED PENDENT
- 200T OR 1/2" BRASS UPRIGHT
- HANGER
- RISE OR DROP NIPPLE
- VCTAULIC COUPLING

- FF K=XX FIN FLR TO CENTERLINE OF PIPE
- C K=XX CEILING TO CENTERLINE OF PIPE
- TJ K=TOP OF JOIST TO CENTERLINE OF PIPE
- BU K=BOTTOM OF JOIST TO CENTERLINE OF PIPE
- BB K=BOTTOM OF BEAM TO CENTERLINE OF PIPE
- ELEV K=OVL ELEVATION OF CENTERLINE OF PIPE

GENERAL NOTES

- ALL DIMENSIONS ARE CENTER TO CENTER U/N
- ALL THREADED PIPE TO BE SCH. 40 BLACK STEEL
- ALL SCREWED FITTINGS TO BE STD. WT. C.I. BLACK U/N
- BB K=BOTTOM OF BEAM TO CENTERLINE OF PIPE
- ALL OTHER FITTINGS TO BE CPVC PLASTIC
- ALL OTHER FITTINGS TO BE CPVC PLASTIC

SYSTEM DESIGN

A WET PIPE SYSTEM OF AUTOMATIC SPRINKLERS TO BE
DESIGNED AND INSTALLED PER NFPA 13R
ALL SPRINKLERS TO BE BASED ON LIGHT HAZARD
MANUAL WET CLASS I STANDPIPE DESIGNED AND INSTALLED PER NFPA 14

REVISION NUMBER	DATE	SURVEYED BY	TITLE
		DATE: 07-12-13	INN AT DIAMOND COVE
		DRAWN BY	MCKINLEY COURT
		APPROVED BY	GREAT DIAMOND ISLAND
		SCALE 1/8" = 1'-0" U/N	PORTLAND, MAINE
		SHEET NO. 1 OF 4	

RESIDENTIAL FIRE PROTECTION, LLC

PHONE (607) 946-3473 FAX (607) 946-3474

64 DAGGETT HILL ROAD GREENE, MAINE 04236