

HYDRAULIC DESIGN INFORMATION SHEET

Name - Inn at Diamond Cove Date - 7-16-13
Location - 3rd floor dwelling unit
Building - System No. - 1 of 1
Contractor - Residential Fire Protection Contract No. - C13015
Calculated By - JAL Drawing No. - 4 of 4
Construction: (X) Combustible () Non-Combustible Ceiling Height 6'-7"
OCCUPANCY - Residential

S Type of Calculation: ()NFPA 13 Residential (X)NFPA 13R ()NFPA 13D
Y Number of Sprinklers Flowing: ()1 ()2 (X)4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 7 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - 100 Gpm Make Viking Model VK468
I Elevation at Highest Outlet - 41.250Feet Size 1/2" K-Factor 4.9
G Note:Safety Margin: 33.595 Temperature Rating 155
N

Calculation Gpm Required 155.570 Psi Required 43.055 At Test
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 6-24-13 Rated Cap. Cap.
T Time of Test - @ Psi Elev.
E Static (Psi) - 81 Elev.
R Residual (Psi) - 27.5 Other Well
Flow (Gpm) - 604 Proof Flow Gpm
S Elevation - 0

P Location:
P
L Source of Information:
Y


Water Supply Curve (C)

RESIDENTIAL FIRE PROTECTION
Inn At Diamond Island

Page 2
Date 7-11-13

City Water Supply:
C1 - Static Pressure : 81
C2 - Residual Pressure: 27.5
C2 - Residual Flow : 604

Demand:
D1 - Elevation : 17.865
D2 - System Flow : 55.57
D2 - System Pressure : 43.055
Hose (Adj City) : _____
Hose (Demand) : 100
D3 - System Demand : 155.57
Safety Margin : 33.595



Fittings Used Summary

RESIDENTIAL FIRE PROTECTION
Inn At Diamond Island

Page 3
Date 7-11-13

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N	CPVC 90'El Harvel-Spears	7	7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Zac	Ames 2000SS	Fitting generates a Fixed Loss Based on Flow																			

Pressure / Flow Summary - STANDARD

RESIDENTIAL FIRE PROTECTION
Inn At Diamond Island

Page 4
Date 7-11-13

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1	41.25	4.9	7.06	na	13.02	0.1	130	7.0
2	41.25	4.9	7.04	na	13.0	0.1	130	7.0
3	41.25	4.9	9.05	na	14.74	0.1	130	7.0
4	40.75	4	13.71	na	14.81	0.1	130	10.6
5	0.0		25.87	na				
6	0.0		29.42	na				
10	0.0		32.07	na				
11	0.0		32.22	na				
12	0.0		32.1	na				
21	0.0		36.11	na				
20	0.0		36.26	na				
30	0.0		37.16	na				
31	0.0		37.28	na				
41	0.0		37.66	na				
40	0.0		37.27	na				
42	8.75		34.18	na				
TR	1.0		37.86	na				
BR	-4.0		44.72	na				
UG1	0.0		43.04	na	100.0			
TEST	0.0		43.05	na				

The maximum velocity is 8.77 and it occurs in the pipe between nodes 5 and 10

Final Calculations - Hazen-Williams

RESIDENTIAL FIRE PROTECTION
Inn At Diamond Island

Page 5
Date 7-11-13

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
1 to 5	13.02	0.874 150	1N	7.0 0.0	3.000 7.000	7.060 17.865			K Factor = 4.90	
	13.02	0.0947		0.0	10.000	0.947			Vel = 6.96	
	0.0 13.02						25.872		K Factor = 2.56	
2 to 5	13.00	0.874 150	1N	7.0 0.0	3.250 7.000	7.039 17.865			K Factor = 4.90	
	13.0	0.0944		0.0	10.250	0.968			Vel = 6.95	
	0.0 13.00						25.872		K Factor = 2.56	
3 to 6	14.74	0.874 150	1N 1O	7.0 3.0	11.000 10.000	9.052 17.865			K Factor = 4.90	
	14.74	0.1191		0.0	21.000	2.502			Vel = 7.88	
	0.0 14.74						29.419		K Factor = 2.72	
4 to 12	14.81	1.101 150	1N 1O	7.0 5.0	7.000 12.000	13.706 17.649			K Factor = 4.00	
	14.81	0.0390		0.0	19.000	0.741			Vel = 4.99	
	0.0 14.81						32.096		K Factor = 2.61	
5 to 10	26.02	1.101 150	5N 2O	35.0 10.0	11.000 45.000	25.872 0.0				
	26.02	0.1107		0.0	56.000	6.199			Vel = 8.77	
	0.0 26.02						32.071		K Factor = 4.59	
6 to 11	14.74	1.101 150	8N 1O	56.0 5.0	11.500 61.000	29.419 0.0				
	14.74	0.0387		0.0	72.500	2.806			Vel = 4.97	
	0.0 14.74						32.225		K Factor = 2.60	
10 to 11	15.01	1.394 150		0.0 0.0	12.100 0.0	32.071 0.0				
	15.01	0.0127		0.0	12.100	0.154			Vel = 3.16	
	0.0 15.01						32.225		K Factor = 2.64	
10 to 12	11.01	1.394 150		0.0 0.0	3.500 0.0	32.071 0.0				
	11.01	0.0071		0.0	3.500	0.025			Vel = 2.31	
	0.0 11.01						32.096		K Factor = 1.94	
11 to 21	29.75	1.394 150	2N 2O	16.0 12.0	58.500 28.000	32.225 0.0				
	29.75	0.0449		0.0	86.500	3.888			Vel = 6.25	
	0.0 29.75						36.113		K Factor = 4.95	
12 to 20	25.82	1.394 150	2N 2O	16.0 12.0	92.500 28.000	32.096 0.0				
	25.82	0.0346		0.0	120.500	4.168			Vel = 5.43	

Final Calculations - Standard

RESIDENTIAL FIRE PROTECTION
Inn At Diamond Island

Page 6
Date 7-11-13

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 25.82					36.264			K Factor = 4.29	
21 to 31	29.75 29.75	1.394 150 0.0450	2O	12.0 0.0 0.0	14.000 12.000 26.000	36.113 0.0 1.169			Vel = 6.25	
	0.0 29.75					37.282			K Factor = 4.87	
20 to 30	25.82 25.82	1.394 150 0.0346	2O	12.0 0.0 0.0	14.000 12.000 26.000	36.264 0.0 0.899			Vel = 5.43	
30 to 31	-18.59 7.23	2.003 150 0.0006	4N	44.0 0.0 0.0	168.250 44.000 212.250	37.163 0.0 0.119			Vel = 0.74	
	0.0 7.23					37.282			K Factor = 1.18	
30 to 40	18.59 18.59	2.003 150 0.0032	2O	20.0 0.0 0.0	13.000 20.000 33.000	37.163 0.0 0.106			Vel = 1.89	
	0.0 18.59					37.269			K Factor = 3.05	
31 to 41	36.98 36.98	2.003 150 0.0115	2O	20.0 0.0 0.0	13.000 20.000 33.000	37.282 0.0 0.380			Vel = 3.77	
41 to 42	0.0 36.98	2.003 120 0.0174	1E 1T	4.29 8.58 0.0	5.000 12.870 17.870	37.662 -3.790 0.311			Vel = 3.77	
	0.0 36.98					34.183			K Factor = 6.33	
40 to 42	18.59 18.59	2.157 120 0.0034	5E 1T	30.767 12.307 0.0	164.000 43.074 207.074	37.269 -3.790 0.704			Vel = 1.63	
42 to TR	36.98 55.57	3.26 120 0.0034	2E 1T	18.815 20.159 0.0	52.750 38.974 91.724	34.183 3.357 0.316			Vel = 2.14	
TR to BR	0.0 55.57	3.26 120 0.0034	1Zac 1Z	0.0 9.408 0.0	7.500 9.408 16.908	37.856 6.806 0.057			* Fixed loss = 4.64 Vel = 2.14	
BR to UG1	0.0 55.57	4.1 140 0.0008	1G 1T	2.907 29.067 0.0	25.000 31.974 56.974	44.719 -1.732 0.048			Vel = 1.35	
UG1 to TEST	100.00 155.57	6.16 140 0.0008		0.0 0.0 0.0	25.000 0.0 25.000	43.035 0.0 0.020			Qa = 100 Vel = 1.67	
	0.0 155.57					43.055			K Factor = 23.71	