



- 120
VD VISUAL ONLY 120VAC
- 120
AV AUDIO/VIDEO 120VAC
- SSV
S SINGLE STATION SMOKE DETECTOR VISUAL 120VAC
- SS
S SINGLE STATION SMOKE DETECTOR 120VAC
- SS
CD SINGLE STATION CO DETECTOR 120VAC
- PS PULL STATION
- S SMOKE DETECTOR
- CD CO DETECTOR
- H HEAT DETECTOR RATE OF RISE
- MH MINI HORN
- V VISUAL ONLY
- AV AUDIO / VISUAL
- NC
100r RELAY MODULE
- TS TAMPER SWITCH
- FS FLOW SWITCH

No.	Revision/Issue	Date
2	Construction Set	6/17/13

Project Name and Address
 Inn at Diamond Cove
 McKinley Court
 Great Diamond Island

Seabee Electric
 COMMERCIAL - INDUSTRIAL
 84 Pleasant Hill Road
 Scarborough, Maine 04074
 (207) 883-5448

Sheet
FA-1.3
 Third Floor Fire Alarm
 Scale
 3/16" = 1'