



- Griddle (Centered)
High Proximity
10.00' L x 18.00' D
- Griddle (Centered)
High Proximity
10.00' L x 18.00' D
- Range-Med (2 -290 per
36")
Low Proximity
24.00' L x 24.00' D
- Oven
High Proximity
30.00' L x 28.00' D
- Oven
High Proximity
30.00' L x 28.00' D
- Oven
High Proximity
34.00' L x 28.00' D

NOTES
 - FIELD PIPE DROPS AS SHOWN
 - SLEEVING, ELBOWS, TEES, AND NOZZLES SUPPLIED BY CAS
 - RELOCATE NOZZLES IF FLOW PATTERN IS BLOCKED BY SLEEVING,
 SALAMANDERS, ETC.
 - MAXIMUM 9 ELBOWS IN SUPPLY LINE.
 - MINIMUM 72 INCHES OF AGENT LINE FROM TANK TO FIRST NOZZLE.
 - IF APPLICABLE, PRE-PIPED CHARBRIQUER DROPS ARE SHIPPED LOOSE.
 - FACTORY PIPING EXTENDS A MAXIMUM OF 6' ABOVE THE TOP OF THE HOOD.
 - APPLIANCE DIMENSIONS LISTED REPRESENT THE COOKING SURFACE
 SIZE, NOT THE OVERALL APPLIANCE SIZE.
 - THIS FIRE SYSTEM COMPLIES WITH UL 300 REQUIREMENTS

LEGEND - WALL MOUNTED ANSUL SYSTEM

- 1A 15 GALLON TANK
- 1B 30 GALLON TANK
- 2 AUTOMAN RELEASE
- 3 3 GALLON TANK ENCLOSURE
- 5 ANSULEX LIQUID AGENT (3 GAL.)
- 6 ANSULEX LIQUID AGENT (1.5 GAL.)
- 9 CARTRIDGE (101-30)
- 10 TEST LINK
- 11 DOUBLE MICROSWITCH
- 2W DUCT NOZZLE (419337)
- IN NOZZLE ASSEMBLY (419335)
- 290 NOZZLE ASSEMBLY (419342)
- 29 DETECTOR BRACKET
- 29 LOW TEMP FUSIBLE LINK
- 30 HIGH TEMP FUSIBLE LINK
- 34 REMOTE MANUAL PULL STATION
- S SWIVEL ADAPTOR

