

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 9 Crescent Ave. P.I. 04108		Owner: Deirdre & Robert Page		Phone: N/A		Permit No: 991377	
Owner Address: SAA		Lessee/Buyer's Name: N/A		Phone: N/A		Business Name: N/A	
Contractor Name: Keith Hulka		Address: 223 Island Ave. P.I. ME 04108		Phone: 766-5780		Permit Issued: DEC 14 1999 CITY OF PORTLAND Zone: CBL: 084-H-015	
Past Use: 1-Family		Proposed Use: Same		COST OF WORK: \$ 15,000		PERMIT FEE: \$ 114.00	
Proposed Project Description: Addition of sunporch to existing deck.		FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: A-3 Type: 53 BOCA 90		Signature: <i>[Signature]</i>	
		Signature: _____		Signature: _____		Zoning Approval: <i>[Signature]</i>	
		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied		Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
Permit Taken By: UB		Date Applied For: 12-8-99		Signature: _____		Date: _____	

- This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
- Building permits do not include plumbing, septic or electrical work.
- Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

4 P. **Please send to: Robert & Deirdre Page
9 Crescent Ave.
Peaks Island, ME 04106

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT	ADDRESS:	DATE: 12-8-99	PHONE:
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE			PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

PERMIT ISSUED
DEC 14 1999
CITY OF PORTLAND
Zone: CBL: 084-H-015

Zoning Appeal
 Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

Historic Preservation
 Not in District or Landmark
 Does Not Require Review
 Requires Review

Action:
 Approved
 Approved with Conditions
 Denied

Date: _____

PERMIT ISSUED WITH REQUIREMENTS

CEO DISTRICT 3

COMMENTS

2/29/00 Son Room Addition Close in ⁽⁵¹³⁾ ₍₂₀₎
8/30/01 Completed.

	Type	Inspection Record	Date
Foundation:	_____	_____	_____
Framing:	_____	_____	_____
Plumbing:	_____	_____	_____
Final:	_____	_____	_____
Other:	_____	_____	_____

BUILDING PERMIT REPORT

DATE: 9 Dec. 99 ADDRESS: 9 Crescent Ave, P.I. CBL: 084-H-015

REASON FOR PERMIT: Addition of sunporch to existing deck-

BUILDING OWNER: Page's

PERMIT APPLICANT: CONTRACTOR Keith Hu ITS

USE GROUP: R-3 CONSTRUCTION TYPE: 513 CONSTRUCTION COST: \$15,000.00 PERMIT FEES: 114.00


The City's Adopted Building Code (The BOCA National Building code/1996 with City Amendments)
The City's Adopted Mechanical Code (The BOCA National Mechanical Code/1993)

CONDITION(S) OF APPROVAL

This permit is being issued with the understanding that the following conditions are met: *1, *2, *11, *13, *27, *29, *33, *34, *36, #31

- 1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained.
3. Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 10 percent material that passes through a No. 4 sieve.
4. Foundations anchors shall be a minimum of 1/2" in diameter, 7" into the foundation wall, minimum of 12" from corners of foundation and a maximum 6' O.C. between bolts.
5. Waterproofing and dampproofing shall be done in accordance with Section 1813.0 of the building code.
6. Precaution must be taken to protect concrete from freezing.
7. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed.
8. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating.
9. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code.
10. Sound transmission control in residential building shall be done in accordance with Chapter 12, Section 1214.0 of the City's Building Code.
11. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level.
12. Headroom in habitable space is a minimum of 7'6".
13. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 1/4" maximum rise.
14. The minimum headroom in all parts of a stairway shall not be less than 80 inches.
15. Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue.
16. Each apartment shall have access to two (2) separate, remote and approved means of egress.
17. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closer's.
18. The boiler shall be protected by enclosing with (1) hour fire rated construction including fire doors and ceiling, or by providing automatic extinguishment.

19. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms
 - In each story within a dwelling unit, including basements
20. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. (Section 921.0)
21. The Fire Alarm System shall maintained to NFPA #72 Standard.
22. The Sprinkler System shall maintained to NFPA #13 Standard.
23. All exit signs, lights and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023.0 & 1024.0 of the City's Building Code. (The BOCA National Building Code/1996)
24. Section 25 – 135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
25. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification the Division of Inspection Services.
26. Ventilation shall meet the requirements of Chapter 12 Sections 1210.0 of the City's Building Code. (Crawl spaces & attics).
- X 27. All electrical, plumbing and HVAC permits must be obtained by a Master Licensed holders of their trade. No closing in of walls until all electrical (min. 72 hours notice) and plumbing inspections have been done.
28. All requirements must be met before a final Certificate of Occupancy is issued.
- X 29. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code (The BOCA National Building Code/1996).
30. Ventilation of spaces within a building shall be done in accordance with the City's Mechanical code (The BOCA National Mechanical Code/1993). (Chapter M-16)
- (31) Please read and implement the attached Land Use Zoning report requirements. *Not to exceed existing footprint of deck*
32. Boring, cutting and notching shall be done in accordance with Sections 2305.3, 2305.3.1, 2305.4.4 and 2305.5.1 of the City's Building Code.
- X 33. Bridging shall comply with Section 2305.16.
- X 34. Glass and glazing shall meet the requirements of Chapter 24 of the building code. (Safety Glazing Section 2405.0)
- X 35. All signage, shall be done in accordance with Section 3102.0 signs of the City's Building Code, (The BOCA National Building Code/1996).
- X 36. *All work shall be done in accordance with the manufactures requirements and the bldg. Code requirements.*

 P. Samuel, Building Inspector
 Cc: Lt. McDougall, PFD
 Marge Schmuckal, Zoning Administrator

PSH 11/25/99

****On the basis of plans submitted and conditions placed on these plans any deviations shall require a separate approval.**

*****THIS PERMIT HAS BEEN ISSUED WITH THE UNDERSTANDING THAT ALL THE CONDITIONS OF THE APPROVAL SHALL BE COMPLETED. THEREFORE, BEFORE THE WORK IS COMPLETED A REVISED PLAN OR STATEMENT FROM THE PERMIT HOLDER SHALL BE SUBMITTED TO THIS OFFICE SHOWING OR EXPLAINING THAT THE CONDITIONS HAVE BEEN MET. IF THIS REQUIREMENT IS NOT RECEIVED YOUR CERTIFICATE OF OCCUPANCY SHALL BE WITHHELD.**

THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED

**Building or Use Permit Pre-Application
Additions/Alterations/Accessory Structures
To Detached Single Family Dwelling**

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

NOTEIf you or the property owner owes real estate or personal property taxes or user charges on any property within the City, payment arrangements must be made before permits of any kind are accepted.**

Location/Address of Construction: <i>9 Crescent St. Peaks Is. 04108</i>			
Tax Assessor's Chart, Block & Lot Number Chart# <i>084</i> Block# <i>H</i> Lot# <i>015</i>		Owner: <i>D & R Page Deirdre & Robert Page</i> Telephone#:	
Owner's Address: <i>9 Crescent Ave</i>		Lessee/Buyer's Name (If Applicable)	Cost Of Work: <i>\$15,000</i> Fee: <i>\$114-</i>
Proposed Project Description:(Please be as specific as possible) <i>Add 10' x 10' room/sunporch to existing deck 1-bam</i>			
Contractor's Name, Address & Telephone <i>Keith Hults 223 E. Ave. Peaks Is 766-5780</i>			Rec'd By: <i>URS</i>

Separate permits are required for Internal & External Plumbing, HVAC and Electrical installation.

- All construction must be conducted in compliance with the 1996 B.O.C.A. Building Code as amended by Section 6-Art II.
- All plumbing must be conducted in compliance with the State of Maine Plumbing Code.
- All Electrical Installation must comply with the 1996 National Electrical Code as amended by Section 6-Art III.
- HVAC(Heating, Ventilation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code.

You must Include the following with you application:

- 1) A Copy of Your Deed or Purchase and Sale Agreement
- 2) A Copy of your Construction Contract, if available
- 3) A Plot Plan (Sample Attached)

If there is expansion to the structure, a complete plot plan (Site Plan) must include:

- The shape and dimension of the lot, all existing buildings (if any), the proposed structure and the distance from the actual property lines. Structures include decks porches, a bow windows cantilever sections and roof overhangs, as well as, sheds, pools, garages and any other accessory structures.
- Scale and required zoning district setbacks

4) Building Plans (Sample Attached)

A complete set of construction drawings showing all of the following elements of construction:


- Cross Sections w/Framing details (including porches, decks w/ railings, and accessory structures)
- Floor Plans & Elevations
- Window and door schedules
- Foundation plans with required drainage and dampproofing
- Electrical and plumbing layout. Mechanical drawings for any specialized equipment such as furnaces, chimneys, gas equipment, HVAC equipment (air handling) or other types of work that may require special review must be included.

Certification

I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant: <i>[Signature]</i>	Date: <i>12/8/99</i>
--	----------------------

Building Permit Fee: \$30.00 for the 1st \$1000.cost plus \$6.00 per \$1,000.00 construction cost thereafter.



From: Keith Hults
223 Is. Ave
Park II ME 04108 766-5780

TO: UNA

re: "page" permit
9 crescent st
Park II. ME

Please del. this fax to
UNA Bentley ASAP.

EXHIBIT A

A certain lot or parcel of land, with the buildings thereon, situated on Peaks Island in Portland, County of Cumberland and State of Maine, on the southerly side of Crescent Avenue, being Lot No. 26 as delineated on plan of building lots of land of J.W. Brackett, easterly from Greenwood Garden, Peaks Island, Maine, as delineated by James B. Jones, Surveyor, which plan is recorded in Cumberland County Registry of Deeds, Plan Book 9, Page 35. Said lot lies on the southerly side of Crescent Avenue and between Lot 24 and 25, on the west and 27 on the east and measures 50 feet or more on said Avenue and extends southerly therefrom 152 feet, more or less, and measures 50 feet on the rear thereof, between the lines of lots 24 and 27.

RECEIVED
RECORDED REGISTRY OF DEEDS

1999 SEP -7 AM 10: 08

CUMBERLAND COUNTY

John B. O'Brien

0066387

287 T81 2256 BK 15029PG 281

P. 02

Warranty Deed
(Maine Statutory Short Form)


Paul Van Cott and Leslie Dame of Portland, Maine, for consideration paid, grant to Deirdro D. Page and Robert J. Page as Joint Tenants, with a mailing address of 19963 Earls Court, Morgan Hill, California 95037 with WARRANTY COVENANTS, the following described real property situated at **9 Crescent Avenue, Peaks Island, Portland, Cumberland County, Maine**

A certain lot or parcel of land with the buildings thereon, situated in said Portland, and being more particularly described on Exhibit A attached hereto and made a part hereof.


Meaning and intending to convey the same premises described in a deed from Kenneth M. Cole, III, dated July 24, 1997, and recorded in the Cumberland County Registry of Deeds in Book 13215, Page 89.

MAINE REAL ESTATE TAX PAID

Witness our hands this Third day of September, 1999.


Witness to all


Paul Van Cott



Leslie Dame
By: Paul Van Cott, as her Attorney-in-Fact

State of Maine
County of Cumberland, ss

September 3, 1999

Personally appeared the above named Paul Van Cott, individually, and as Attorney-in-Fact on behalf of Leslie Dame and acknowledged the foregoing instrument to be his free act and deed and his free act and deed in said capacity.


Before me,


Notary Public/Attorney at Law

Printed Name:

KENNETH E. SNITZER
MAINE ATTORNEY AT LAW

Comm. Exp.



Add sun porch to existing deck

Existing Deck

House

D. & R Page .766-9749
 9 Coescent Rd
 Peaks Is ME
 084-1-015
 IR=D

Inspection Services
Michael J. Nugent
Manager




Department of Urban Development
Joseph E. Gray, Jr.
Director


CITY OF PORTLAND

Congratulations!!!!!!

Building or Use Permit Application Additions/Alterations/Accessory Structures To Detached Single Family Dwelling

As an applicant for a building permit, you are about to enter into a relationship with our Office. We welcome any questions, comments or suggestions that will make the process more efficient. Attached you will find an application and some samples of the submissions you will provide at application time. Please read ***ALL*** of the information and if you need any further assistance please call 874-8703 or 874-8693.





PRO-SEAL™


The Professional Glazing System

GENERAL SPECIFICATIONS: PRO-SEAL™ is a two piece (base and cap) extruded aluminum glazing system with EPDM rubber gaskets. It has an internal guttering system that prevents leaks and weeps away condensation. It is non-structural and requires a supporting frame. Use to mount glass or plastic glazing on any vertical or sloped application. Minimum recommended pitch is 3 on 12.

ALUMINUM EXTRUSIONS: 6063-T5 aluminum with factory baked PPG Polycron III™ finish. Standard colors are white and quaker bronze. Extrusions are available in 8', 12', 16', 20', and 24' lengths.


GASKETS: Extruded 70 durometer EPDM rubber. It has superior ultraviolet light resistance with 20+ years of life expectancy and a service temperature of -60F to +250 F.

FASTENERS: All fasteners are stainless steel. The Attaching Screw is a #10 x 2" hex head screw. Glazing cap screws are 1/4"-20" hex cap screws with sealing washers.




PERIMETER ASSEMBLY


MULLION ASSEMBLY



PURLIN ASSEMBLY



1" PERIMETER ASSEMBLY



1/4" PERIMETER ASSEMBLY

PRO-SEAL SHAPES: The **Perimeter Bar** mounts around the perimeter of the glazing; top, sides & bottom. Available with or without a thermal break, it accommodates from 1/4" to 1 1/2" glazing. The **Mullion Bar** joins the glazing vertically and the **Purlin Bar** connects it horizontally. The purlin overlaps the gutters of the mullion for leak-proof drainage. The **Glazing Cap** screws into the perimeter or mullion securing the glazing. A **Trim Cover** hides the screws. Use the **Bevel Cap** on sloped applications to cap all the purlins and the bottom perimeter.



ABUNDANT ENERGY INC.

P.O. Box 307, Pine Island, NY 10969
1-800-426-4859 Fax: 914-258-4023