

CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
 389 Congress Street
 Portland, Maine 04101

Inspection Violations

Owner/Manager CARTER G WILLIAM III &		Inspector Suzanne Hunt	Inspection Date 2/12/2009
Locatation 28 ADAMS ST	CBL 084 M001001	Status Re-Inspect 14 Days	Inspection Type Complaint-Social Services/Gener

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 110.26 (b)	Interior				
Violation:	NEC 2005/NFPA 70				
Notes:	one smoke detector in each bedroom and one in the vicinity of the bedrooms, minimum of one on each level, including basement, hardwired, interconnected with battery backup. NFPA Life Safety Code				

Comments: fail, No smokes in building, smokes required on all floors, in each bedroom, and one in vicinity of bedrooms , interconnected with battery back up required. Smh