

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK
CITY OF PORTLAND

Please Read
Application And
Notes, If Any,
Attached

BU **PERMIT** ION

Permit Number: 090248
PERMIT ISSUED
APR - 9 2009
CITY OF PORTLAND

This is to certify that LAGOULIS JAMES & GEORGE W. CLARK & SONS JONES LTD

has permission to Raise the Lower Deck to be Level with the Higher Deck, Raising 2"

AT 6 WELCH ST, PEAKS ISLAND CL 084 Q003001

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and written permission procured before this building or part thereof is lath or other work is set-in. 24 HOUR NOTICE IS REQUIRED.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS

Fire Dept. *Bjornvall*

Health Dept. _____

Appeal Board _____

Other _____
Department Name

Cheryl M. 4/9/09
Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD

SCANNED

CLOSED SMH 5/21/09

4/23/09 checked new framing
good to psur.
From front 11' span @ 1600 2x10
SPAN
7.6 ~~2x~~ (2x10) - left half -
OK smt
checked existing deck
Contractor replaces Gazebo
old section kept it was damaged.

5-13-09
Stain noising incurred smt

5/21/09
NO NOISING - correct
completed
Close permit smt

note(s) footings were installed to
@ 4FT deep
Support Awning ~~to~~
under center levered front of
deck smt.