04108

DATE 2017.12.29 REVISED

Sla Island S <u>م</u> O

CONSTRUCTION SYSTEMS

CEDAR SHINGLES ON VENTED MESH OR – CLAPBOARDS ON VERTICAL RAINSCREEN STRAPPING . — WEATHER BARRIER — - EX'G BOARD SHEATHING ---- EX'G FRAMING -Ô -1/2" GWB. FINISHED · -DENSEPACK CELLULOSE INSULATION -–2X4 STUDS @ 16" O.C. —

R-VALUE CALCULATIONS

ASSEMBLY R-VALUES BY PARALLEL PATH CALCULATION METHOD

DOUBLE STUD WALL (NEW WALL INBOARD OF

2" EXTRUDED POLYSTYRENE OVER ROOF

SHEATHING . EXISTING TO REMAIN.

16" LOOSE FILL CELLULOSE

EX'G) w 10" DENSE-PACK CELLULOSE INSULATION

4" EXTRUDED POLYSTYRENE BELOW 4" CONCRETE

3" CLOSED-CELL POLYURETHANE SPRAY FOAM APPLIED TO INTERIOR OF SHEATHING

(WEIGHTED 75% CAVITY, 25% STUDS PLATES, HEADERS):

EXTERIOR WALLS:

EXISTING ROOF:

NEW FLAT CEILINGS: R-55

GROUND FLOOR SLAB: R-20

PERIMETER SKIRTING: R-18

PROVIDE MOISTURE RESISTANT GWB IN BATHROOMS. PROVIDE SOUND ATTENUATING BATTS AT DEMISING WALLS, BATHROOM WALLS,

SEALING OF BUILDING ENVELOPE

PENETRATIONS IN INSULATING MATERIALS PROPERLY SEALED.

AROUND WINDOW & DOOR FRAMES.

EXTERIOR WALLS, FLOORS, & CEILINGS.

JOINTS BETWEEN EXTERIOR AND INTERIOR WALLS

SERVICE AND ACCESS DOORS & HATCHES.

UNDER THRESHOLDS.

OPENINGS IN THE ATTIC FLOOR.

RECESSED LIGHTING FIXTURES.

AREAS TO BE SEALED INCLUDE BUT NOT LIMITED TO THE FOLLOWING:

BETWEEN WALL ASSEMBLIES AND THEIR SILL PLATES & FOUNDATIONS.

WHERE METAL & CONCRETE OR METAL & MASONRY ASSEMBLIES MEET.

LEAKAGE.

EXTERIOR OPENINGS, JOINTS, CRACKS, & HOLES IN THE BUILDING ENVELOPE TAPED, CAULKED,

GASKETED, WEATHERSTRIPPED, OR OTHERWISE SEALED WITH A FLEXIBLE MATERIAL TO LIMIT AIR

OPENINGS FOR PLUMBING, ELECTRICAL WIRING, AIR DUCTS, REFRIGERANT, & GAS LINES IN

BUILDING ENCLOSURE NOTES

ALL FIRE RATED PARTITIONS SHALL BE STENCILED ON WALL SURFACE ABOVE THE CEILING LINE WHERE ACCESSIBLE INDICATING RATING IN RED PAINT ON EACH

EXTEND SMOKE, SOUND, & FIRE PARTITIONS TO UNDERSIDE OF FLOOR/ROOF

DECK U.N.O., SEAL TO DECK & FILL VOIDS BETWEEN FOR SMOKE AND SOUND

CONTRACTOR IS RESPONSIBLE TO VERIFY FIELD CONDITIONS AND MODIFY CLOSURE DETAILS TO MEET ACTUAL CONDITIONS AND TO MANTAIN CONTINUTITY OF PARTITIONS FROM FLOOR TO DECK ABOVE.

SLEEPING ROOM WALLS.

CONNECT & SEAL TO STRUCTURE. CONNECT & SEAL TO STRUCTURE. FIRESTOP ALL PENETRATIONS. FIRESTOP ALL PENETRATIONS. - SOUND ATTENUATION BATTS SOUND ATTENUATION BATTS (AS REQ'D, SEE NOTES) CEILING (AS REQ'D, SEE NOTES) CEILING __ -5/8" TYPE FC30 GWB, FINISHED -5/8" TYPE -X GWB, FINISHED -WOOD STUDS @ 16" O.C. -WOOD STUDS @ 16" O.C. PLAN VIEW PLAN VIEW HOLD GWB OFF FLOOR, SEAL JOINT HOLD GWB OFF FLOOR, SEAL JOINT w/ NON-HARDENING SEALANT~ w/ NON-HARDENING SEALANT FLOOR LINE SECTION VIEW

1 HOUR RATED ASSEMBLY #UL305

FLOOR LIN

WINDOW SPECIFICATIONS

U-VALUE

SHGC

VLT

VINYL WINDOW UNITS w/ 7/8" LOW-E CLEAR ARGON FILLED INSULATED GLASS

0.31

0.29

0.49

SECTION VIEW

PLAN VIEW SECTION VIEW

RATED WALL TYPES

1/2 HOUR RATED ASSEMBLY #UL407

1"=1'-0"

EXTERIOR WALL TYPE

EX'G EXTERIOR WALL w/ INTERIOR SECOND STUD WALL & CELLULOSE INSULATION

WALL TYPE NOTES