



ınd, ME Ave Isla Island eaks

BUILDING SECTION

BUILDING SECTION 1/8"=1'-0"

-2" XPS BELOW ROOFING TO REMAIN.

VAPOR BARRIER

23'-6"
SECOND FLOOR
RIDGE 2-HR DEMISING WALL WITH SOUND INSULATION. CARRY RATED ASSY TO 12" DENSE PACK INSULATION ADDED UNDERSIDE OF ROOF DECK 18'-8 FIRST FLOOR RIDGE APT #2 LOFTED CEILING/NO ATTIC ♦ 9'-2 SECOND FLOOR EXISTING FIELD MODIFIED TRUSSES TO BE REPAIRED, SEE S2.1 9' CEILING ABOVE 30 MINUTE HORIZONTAL — ASSEMBLY BETWEEN DWELLING UNITS. - 30 MINUTE HORIZONTAL ASSEMBLY BETWEEN DWELLING UNITS OFFICE SPACE **BUSINESS OCCUPANCY** APT #1 APT #4 ♦ 0'-0"
FIRST FLOOR 0'-0" FIRST FLOOR ◆ STORAGE APT #3 ⊕ -9'-6" GROUND FLOOR GROUND FLOOR NEW FOOTINGS, FOUNDATIONS, & OTHER STRUCTURAL UPGRADES PER DRAWINGS PERMITTED 05.04.2017 2-HR SEPARATION _2" XPS WING INSULATION OVER BETWEEN RESIDENTIAL & STORAGE OCCUPANCIES SHALLOW FROST-PROTECTED FOOTING 4" XPS OVER SUB-SLAB