Ⓔ - EMERGENCY ESCAPE AND RESCUE OPENING WINDOW.

- MIN NET CLEAR OPENING AREA 5.7 S.F.
- MIN NET CLEAR OPENING HEIGHT 24"
- MIN NET CLEAR OPENING WIDTH 20"
- MIN NET CLEAR OPENING HEIGHT A.F.F. 44"

Ⓣ - TEMPERED SAFETY GLASS REQ'D AT WINDOWS :

- GLASS AREA > 9 S.F. &
- BOTTOM OF GLASS <18" A.F.F &
- TOP OF GLASS >36" A.F.F &
- WALKING SURFACE WITHIN 36".

3 WINDOW SCHEDULE

1/4"=1'-0"

2 EAST ELEVATION

1/8"=1'-0"

NOTE: FOREGROUND
DECK NOT SHOWN

1 WEST ELEVATION

1/8"=1'-0"

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 04/24/18

Rachel Conly
26 Sterling
Peaks Island
207.766.562
www.rachelcc

DATE	NOTES
2017.12.29	ISSUED FOR PERMIT
REVISED 2018.01.16	1 TWO HOUR GROUP SEPARATION
2018.02.02	2 REVISED SITE - WALKWAY & RAMP
2018.02.22	3 SEPARATION DTLS & 1HR RATING @ SOUTH WALL

PROJECT

2 Island Ave.
Peaks Island, ME

EAST & WEST
ELEVATIONS

A2.2