




Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/28/14



Indoor Unit

Located on the main floor of the h
living area on the exterior wall.

Weight of unit is 22 lbs. Unit to be mounted to wall
framing with 2.5" fasteners sufficient to support the
unit.

Outdoor Unit

Located under the front porch on the south end of the
home.

Weight of unit is 88 lbs. Minimum of 4 3" stainless
steel lag bolts to attach bracket.

Notes:

Home is built of traditional wood framing and is
sufficient to support the additional load of the
equipment being installed.

ReVision Energy	HVAC Equipment Layout				
	MacRae Residence 50 Oak Avenue, Peaks Island, ME				
142 Presumpscot Street Portland, Maine, 04097 207-221-6342	DATE 4/21/2014	DRAWN BY Geoff Sparrow	PAGE 1 of 1	DWG# 1	Rev. 0