

Air Source Heat Pump Locations



Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 10/05/15

Humphrey Johnson
34 Oakland Ave
Peaks Island, ME 04108

System Type:

Air Source Heat Pumps

Drawing Name:

Site Map

Page: 1 of 1

Drawn By: L. Brostek

Date: September 28, 2015

Rev. Number: 0


Project Design Notes:

- (1) Mitsubishi MSZ FH12 Interior Unit
Rated Capacity 12,000 Btu / hr
Mounted to wall frames
Weight of unit is 29 lbs
- (1) Mitsubishi MUZ FH12 Exterior Unit
Rated Capacity 12,000 Btu / hr
Installed on wall-mount bracket
Weight of unit is 83 lbs

© Copyright ReVision Energy

This diagram is provided as a service and is based on the understanding of the information supplied. It is subject to change based on actual conditions, applicable edition of the National Electric Code, and local governmental authorities.

Professional Engineer Stamp of Approval:



Note: Home is built of traditional wood framing and is sufficient to support the additional load of the equipment being installed.