Inspections Division
Date: 02/12/15

Note: Porch post layout based on dividing porch roof span into thirds. Overall Stair width determined by aligning newel posts with porch posts.

NOTES:
1.)ALL WOOD FRAMING MEMBERS THAT REST ON CONCRETE OR MASONRY EXTERIOR WALLS OR ARE LESS THAN 8" FROM THE EXPOSED GROUND SHALL BE OF A ROT RESISTANT MATERIAL

2.)ALL WOOD JOISTS OR THE BOTTOM OF A WOOD STRUCTURAL FLOOR WHEN CLOSER THAN 18", OR WOOD GIRDERS WHEN CLOSER THAN 12", TO THE EXPOSED GROUND, SHALL BE OF A ROT REISTANT MATERIAL.

3.)NEW WOOD SIDING AND/OR SHEATHING TO BE ABOVE GRADE A MINIMUM OF 6" OR ELSE OF A ROT RESISTANT MATERIAL.

4.) ALL DECK/STAIR FRAMING/DECKING TO BE OF ROT RESISTANT WOOD.

⊠ pressure treated 6X6

FASTENER SCHEDULE	
SILL PLATE TO FOUNDATION	1/2" ANCHOR BOLT @ 36" O.C. W/ 3" PLATE WASHER; 9" MIN. EMBEDMENT
ROOF SHEATHING	8d @ 6" O.C. EDGE / 12" O.C. FIELD (TYPICAL PANELS) 8D @ 6" O.C. EDGE / 6" O.C. FIELD (PERIMETER PANELS)
WALL SHEATHING	8d @ 6" O.C. EDGE / 12" O.C. FIELD
FLOOR SHEATHING	12d RING OR SPIRAL NAILS @ 6" O.C. EDGE / 12" O.C. FIELD
POST BASES TO CONCRETE	SIMPSON TYPE AB
POST CAPS	SIMPSON BC OR LC (MATCH POST SIZE)
JOIST ON SILL, TOP PLATE, OR GIRDER	SIMPSON LUS HANGER OR 4 – 8d (TOENAILED) WHEN JOIST BEARS ON SUPPORT
BRIDGING / BLOCKING TO JOIST	2 – 8d (TOENAILED)
BLOCKING TO SILL / TOP PLATE	3 – 16d (TOENAILED)
LEDGER STRIP TO BEAM	3 – 16d (FACENAILED, PER JOIST)
JOIST ON LEDGER TO BEAM	3 – 8d (TOENAILED)
BAND / RIM JOIST TO JOIST	3 – 16d (ENDNAILED)
RIM JOIST TO SILL / TOP PLATE	2 – 16d PER FOOT
TOP PLATE TO TOP PLATE	2 – 16d PER FOOT
TOP PLATES AT INTERSECTION	4 – 16d EACH SIDE
STUD TO STUD	1 – 16d @ 12" O.C.
HEADER TO HEADER	16d @ 8" O.C. ALONG EDGES
TOP OR BOTTOM PLATE TO STUD	2 – 16d
BOTTOM PLATE TO JOIST OR BLOCKING	2 – 16d PER FOOT
RAFTER TO TOP PLATE	SIMPSON H1 HURRICANE TIE
CEILING JOIST TO TOP PLATE	2 – 8d (TOENAILED)
BLOCKING TO RAFTER	2 – 8d EACH END
BAND JOIST TO RAFTER	2 – 16d EACH END
SLOPED/SKEWED RAFTER HANGERS AT RIDGE/HIP BEAMS	SIMPSON LSU

0 1 2 3 4 5 6

Ⓐ Proposed Porch Roof Framing Plan
1/4" = 1'-0"

Rachel Conly
Architectural Design

26 Sterling Street
Peaks Island, Maine 04108
207.766.5625

Proposed Porch Roof Framing Plan

STATE OF MAINE
ANDREW M. JACKSON
No. 13082
LICENSED
PROFESSIONAL ENGINEER

PROJECT

Carter Residence
19 Merriam St.
Peaks Island, ME
04106

DATE	REVISED
12.20.14	02.10.15
SCALE 1/4"=1'-0"	DRAWN BY Rachel & Harvey

NOTES

S3