

PERMIT ISSUED

City of Portland, Maine - Building or Use Permit Application
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 02-1346 Issue Date: DEC 10 2002 CBL: 085 M003001

Location of Construction: 255 Brackett Ave Owner Name: City Of Portland Owner Address: 389 Congress Street Phone: CITY OF PORTLAND Business Name: n/a Contractor Name: Sheldons Plumbing & Heating Contractor Address: 31 Peary Terrace South Portland Phone: 2077996211 Lessee/Buyer's Name: n/a Phone: n/a Permit Type: HVAC Zone:

Past Use: Residential Proposed Use: Install 275 gallon oil tank Permit Fee: \$30.00 Cost of Work: \$0.00 CEO District: 3 FIRE DEPT: [] Approved [] Denied INSPECTION: Use Group: Heating Type:

Proposed Project Description: Install heating system PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: [] Approved [] Approved w/Conditions [] Denied Signature: Date:

Permit Taken By: gg Date Applied For: 12/06/2002 Zoning Approval

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. 2. Building permits do not include plumbing, septic or electrical work. 3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.. Special Zone or Reviews [] Shoreland [] Wetland [] Flood Zone [] Subdivision [] Site Plan Maj [] Minor [] MM [] Date: Zoning Appeal [] Variance [] Miscellaneous [] Conditional Use [] Interpretation [] Approved [] Denied Date: Historic Preservation [x] Not in District or Landmark [] Does Not Require Review [] Requires Review [] Approved [] Approved w/Conditions [] Denied Date: 12/10/02

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.


SIGNATURE OF APPLICANT ADDRESS DATE PHONE

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE DATE PHONE



FILL IN AND SIGN WITH INK

02 1346



APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

085 M 003

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 255 Brackett Use of Building _____ Date 12-6-02

Name and address of owner of appliance CITY OF PORTLAND PEAK'S ISLAND
PUBLIC WORKS 255 BRACKETT AVE.

Installer's name and address SHELDON GOLDMAN 31 PEARLY TERRACE SO. PORTLAND
SOUTHERN MAINE PLUMBING 160 PRESUMPSUIT ST. PORTLAND Telephone 799-6211 / 772-5203

MLD

Location of appliance:

- Basement
- Floor GARAGE
- Attic
- Roof

Type of Fuel:

- Gas
- Oil
- Solid

Appliance Name: WEIL McLAIN W60-8

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # MS 3000 2800
- Oil # _____
- Gas # _____
- Other _____

Type of Chimney:

- Masonry Lined
Factory built _____

- Metal
Factory Built U.L. Listing # MEETS ALL

- Direct Vent
Type _____ UL# _____

Type of Fuel Tank

- Oil
- Gas

Size of Tank 275 GAL DE HOUST / GRANBY

Number of Tanks 2

Distance from Tank to Center of Flame 7 feet.

Cost of Work: \$ 30,000

Permit Fee: \$ _____

Approved

Approved with Conditions

Fire: _____

Ele.: _____

Bldg.: [Signature]

- See attached letter or requirement

[Signature]
Inspector's Signature

Date Approved

Signature of Installer _____

PERMIT INFO

PEAK'S ISLAND
PUBLIC WORKS BUDG

255 BRACKETT AVE
PEAK'S ISLAND

BUR: WEIL MCLAIN WGO-8
231 MBTU
2.3 GAL FIRING RATE

CHIMNEY: 8" SSII METALBESTUS

2 - 275 GAL DEHOUST/GRANBY
DOUBLE WALL OIL TANKS

ZONE #1 → 3 MODINE VB-104 VERTICAL UNIT HEATERS
(68,000 BTU, 55 LBS)

ZONE #2 → SWANTON 30 RADIATION

HOT WTR → 60 GAL SUPERSTORE WTR HTZ.