

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 17 Eighth Maine Ave, Peaks Isl		Owner: Desousa, Robert & Annette		Phone: 766-2175		Permit No: 960553	
Owner Address: SAA 04108		Leasee/Buyer's Name:		Phone:		Business Name:	
Contractor Name: Cottage Renovations		Address:		Phone:		Permit Issued: JUN 19 1996 CITY OF PORTLAND	
Past Use: 1-122		Proposed Use: Same		COST OF WORK: \$ 450.00 PERMIT FEE: \$ 25.00 FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied INSPECTION: Use Group: Type:		Zone: CBL: 085-N-012 Zoning Approval: Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan <input type="checkbox"/> maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
Proposed Project Description: Install Skylight Remove/Enlarged Window		PEDESTRIAN ACTIVITIES DISTRICT (P.U.D.) Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Signature: _____ Date: _____		Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Historic Preservation <input checked="" type="checkbox"/> Not in District or Landmark <input checked="" type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Date: 6/19/96			
Permit Taken By: Mary Gresik		Date Applied For: 10 June 1996		1. This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules. 2. Building permits do not include plumbing, septic or electrical work. 3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..			

PERMIT ISSUED WITH LETTER

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT	Anette Desousa	ADDRESS:	10 June 1996	DATE:	PHONE:
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE					PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

CEO DISTRICT **6**
A Point

Inspection Services
P. Samuel Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

June 17, 1996

Robert & Anette DeSousa
17 Eight Maine Ave.
Peaks Islnd, Maine 04108

Dear De Sousa:

Your application to install a skylight and enlarge one window has been reviewed and a permit is herewith issued with the following requirements: This permit does not excuse the applicant from meeting applicable State and Federal Rules and regulations.


1. This permit is being issued with the understanding that the existing rafters will not be cut .
2. The proposed skylight glass shall meet the requirements of section 2404.0 of the city's building code (THE BOCA NATIONAL BUILDING CODE /1993) .

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,




P. Samuel Hoffses
Chief of Inspection Services



Skylite framing 24" skylite set into
 Existing Rafters 25 o.c. headed off w/ doubled
 2x4 All existing framing
 is 2x4 stock
 Approximate cost \$2500⁰⁰

facing west window 42 x 40
 casement window



2x8 header
 2x4 king cripples
 2x4 Jack studs
 US60 window
 Labor cost \$200⁰⁰

~~All work~~ to be Framing & window
 Installation by Collage Renovations
 Finish & clean up done by home owner.