



DO NOT BOTTOM
ENTRY ANY CONDUIT
IN ANY PANEL

SYMBOL LEGEND

- PULL STATION
- SMOKE DETECTOR
- HEAT DETECTOR RATE OF RISE
- HEAT DETECTOR Fixed Temp (135°, 200°)
- VISUAL ONLY
- AUDIO / VISUAL
- MOTION DETECTOR WALL MOUNTED
- KEYPAD
- GAS MTECTOR

CABLE LEGEND

- EOLR END OF LINE RESISTOR
- H 1 pr 116 AWG CABLE
- K 1 pr S20 AVG CABLE

COMMENTS

NOTE 1: This is a typical layout, wiring is shown diagrammatically only. Riser does not necessary indicate all devices and appliances. See floor plans and specification for location and quantities. The purchaser needs to accurately layout the devkes in their proper zones. IF partitions are NOT known homerun each device back to the control panel.

NOTE 2: If connecting a fire panel to the security panel for reporting means. Dual phone lines and an additional module is required for UL listing.

REVISION 2	DATE:
REVISION 1	DATE:
REVISION 0 SUBMITTAL	DATE: 05-28-2004

SYSTEM WIRING RISER	
PROJECT NAME	SCALE NTS
8th Maine Memorial	BY: KNOWLTON
PEAKS ISLPND, PORTLAND, MAINE	CK BY:
NORRIS INC.	
P.O. BOX 2551, SWTH PORTLAND, MAINE 04116	SAVED AS:
2257 BROADWAY, SOUTH PORTLAND, MAINE	MAINEMEMORIA