Inspections Division
Date: 09/25/14

Rand 17 3rd Street Peaks Island
Proposed New Stairs

rail height 34" off nose of tread

5/4 stair treads

7" rise - 12" tread

1" noising

2x12 pt stair stringer, 16" oc