




Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/18/15



20,000 BTU/hr Mitsubishi MXZ-2C20NAHZ
H2i Multi-Zone Outdoor Condenser Unit
Installed on wall-mounted bracket on back of the
house above the flood plain.
Weight of unit is 187 lbs.

12,000 BTU/hr Mitsubishi MSZ FH12 Indoor Unit
Mounted to wall framing in the living room facing
toward the kitchen (first floor).
Weight of unit is 29 lbs.

9,000 BTU/hr Mitsubishi MSZ FH09 Indoor Unit
Mounted to wall framing at top of the stairs
facing toward the two bedrooms (second floor).
Weight of unit is 29 lbs.



Notes:

Home is built of traditional wood framing and is sufficient to support the additional load of the equipment being installed.

ReVision Energy		HVAC Equipment Layout		
142 Presumpscot Street Portland, Maine, 04097 207-221-6342		Joe and Janet Moan 186 Seashore Ave, Peaks Island ME		
DATE	DRAWN BY	PAGE	DWG#	Rev.
5/6/2015	Luke Brostek	1 of 1	1	0