Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 06/26/14

Outdoor Unit – Master Bedroom
Located on blocking on the secon
side the master bedroom.

Weight of unit is 88 lbs. Shall be r
material

Indoor Unit – Finished Basement
Located in the southeast corner high on the wall.

Weight of unit is 22 lbs. Unit to be mounted to wall framing with 2.5" fasteners sufficient to support the unit.

Indoor Unit – 1st Fl.
Located in living room high up on the exterior wall

Weight of unit is 22 lbs. Unit to be mounted to wall framing with 2.5" fasteners sufficient to support the unit.

Outdoor Unit – 1st Fl.
Located at ground level and will be mounted to a self supporting stand on concrete blocks.

Weight of unit is 88 lbs.

Notes:
Home is built of traditional wood framing and is sufficient to support the additional load of the equipment being installed.

ReVision Energy	HVAC Equipment Layout				
142 Presumpscot Street Portland, Maine, 04097 207-221-6342	Paul Castle 308 Seashore Avenue, Peaks Island, ME				
	DATE 6/17/2014	DRAWN BY Geoff Sparrow	PAGE 1 of 1	DWG# 1	Rev. 0