Inspections Division
Date: 12/23/13

Outdoor Unit
Located under roof of covered porch and supported by a bracket attached to the wall framing members.

Weight of unit is 88 lbs. Minimum of 4 3" stainless steel lag bolts to attach bracket.

Indoor Unit
Located in the first floor of the home in the main living area on the exterior wall.

Weight of unit is 22 lbs. Unit to be mounted to wall framing with 2.5" fasteners sufficient to support the unit.

Notes:
Home is built of traditional wood framing and is sufficient to support the additional load of the equipment being installed.

ReVision Energy	HVAC Equipment Layout				
142 Presumpscot Street Portland, Maine, 04097 207-221-6342	Higgins Residence 320 Seashore Avenue, Peaks Island, ME				
	DATE 12/17/2013	DRAWN BY Geoff Sparrow	PAGE 1 of 1	DWG# 1	Rev. 0