



Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/03/18

Building Permit #2017-01190, 89 Pleasant Ave., PI

1/31/18

Please provide the remaining items:

Code review per the [One and Two Family Addition/Alteration Checklist](#):

1. Structural plans for the modified shipping container.
2. Structure anchoring specifications and details.
3. Footing & pier dimensions, depth, and reinforcement.
4. Insulation R-factor levels for floor, walls and ceiling.
5. Window and door schedule including U-factor levels.
6. Smoke and carbon monoxide locations.
7. Construction of any new exterior landing, steps and railings based on the height off grade.

Remaining items per the Residential Shipping Container Policy:

1. A letter of intent from the applicant with the selected option and information as described in the policy.
2. The manufacturer's documentation letter, as described in the policy, except for the letters from the licensed plumbing and electrical installers. If any HVAC installations will be done at the factory, this information is required for the licensed installer.

Please note that additional information may be requested if the information provided is lacking essential detail or content.