

**BAKER DESIGN CONSULTANTS**  
Civil, Marine and Structural Engineering

# 87-00-007

Date: 9/22/2009  
To: Dawn Hallowell- Maine DEP  
Jay Clement- Army Corps of Engineers; Maine Project Office  
Jeff Liick- Portland Harbor Commissioners  
Barbara Barhydt - City of Portland Planning; Development Review Services Manager  
Marge Schmuckal- City of Portland Zoning  
Shukria Wiar- City of Portland Planning  
Lannie Dobson- City of Portland Code Enforcement  
Philip DiPierro- City of Portland Development Review Coordinator  
From: Barney Baker PE  
Copy: File, Charlie Poole -Custom Floats, William Zimmerman  
Subject: Zimmerman Pier Extension, Peaks Island-Project Inspection-Punchlist  
ACOE Permit: CENAE-R-NAE-2006-03673  
DEP Permit: L-23320-4P-D-N & L-23320-TW-E-N  
Portland Bldg. Permit: 090750  
Portland Site Plan Ref: 0999600002


No. of Pages (inc. this sheet): 1

C:\BDC\3500\_PROJECT\80808-29\_ZIMMERMAN\_PIER\PERMITTING\PERMITS\_RECEIVED\BDC\_INSPECTION.DOCX

## MEMO

This memo follows a 09.17.09 site inspection meeting with Barney Baker PE of Baker Design Consultants, Charlie Poole of Custom Float Services and Philip DiPierro of the City of Portland. The work was found to be Substantially Complete and in accordance with the design drawings and permits obtained for the pier extension. The following list includes additions & punchlist items that will be addressed by Custom Floats.

- Adjust/Tighten tension chains on Lifting Frame
- Add Caps to protect top of float guide piles
- Add crossbar for storm gangway support
- Add hinge plate at top of gangway to clear gap and secure deck board
- Trim Pile Cap at outer bent.



11 STONY BROOK LANE, YARMOUTH, ME 04096

T: (207) 846-9724

F: (207) 846-3620

EMAIL: bbaker@maine.rr.com