

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**

OLDHAM SARAH G & THEODORE OLDHAM JTS

**Located at**

154 ISLAND AVE

**PERMIT ID:** 2016-00960

**ISSUE DATE:** 07/21/2016

**CBL:** 087 00019001

has permission to **Construct three sets of wooden steps and four wooden landings to access water.  
All steps and landings will be 4' wide or less.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Doug Morin

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

*Approved Property Use - Zoning*  
single-family seasonal

*Building Inspections*

*Fire Department*

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

## **REQUIRED INSPECTIONS:**

Setbacks and Footings Prior to Pouring

Framing Only

Final Inspection

Final - DRC

Site VISIT

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2016-00960	<b>Date Applied For:</b> 04/21/2016	<b>CBL:</b> 087 00019001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> Single Family	<b>Proposed Project Description:</b> Construct three sets of wooden steps and four wooden landings to access water. All steps and landings will be 4' wide or less.			
<p><b>Dept:</b> Zoning      <b>Status:</b> Approved w/Conditions      <b>Reviewer:</b> Christina Stacey      <b>Approval Date:</b> 07/18/2016</p> <p><b>Note:</b> I-B zone, SZ      <b>Ok to Issue:</b> <input checked="" type="checkbox"/></p> <p>Per §14-449(a)(1)(b) - no setback required for structures Water access stairs and landings, all &lt;4' in width - OK Approved planting plan to address removal of bittersweet</p> <p><b>Conditions:</b></p> <ol style="list-style-type: none"> <li>1) This property shall remain a single family seasonal dwelling. Any change of use shall require a separate permit application for review and approval.</li> <li>2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.</li> <li>3) The trees and shrubs to be planted in the shoreland zone shall be monitored and replaced as necessary to achieve a minimum survival rate of 80% for three years after planting.</li> </ol>				
<p><b>Dept:</b> Building Inspecti      <b>Status:</b> Approved w/Conditions      <b>Reviewer:</b> Doug Morin      <b>Approval Date:</b> 07/06/2016</p> <p><b>Note:</b>      <b>Ok to Issue:</b> <input type="checkbox"/></p> <p><b>Conditions:</b></p> <ol style="list-style-type: none"> <li>1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.</li> <li>2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.</li> </ol>				
<p><b>Dept:</b> DRC      <b>Status:</b> Approved w/Conditions      <b>Reviewer:</b> Philip DiPierro      <b>Approval Date:</b> 07/21/2016</p> <p><b>Note:</b>      <b>Ok to Issue:</b> <input checked="" type="checkbox"/></p> <p><b>Conditions:</b></p> <ol style="list-style-type: none"> <li>1) See site plan approval letter dated July 11, 2016 (site plan approved on July 11, 2016) for conditions of approval.</li> </ol>				