

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

KONZAL GREGORY S & ANGELA KONZAL JTS

Located at

47 CENTENNIAL ST (5 City Point Rd)

PERMIT ID: 2015-01510

ISSUE DATE: 07/30/2015

CBL: 087 U001001

has permission to **Installing an emergency standby generator on concrete pad (5'8" x 10'2") to provide backup power in case of power failure (Located on property known as 5 City Point Road)**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Jeanie Bourke

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Waste Water Pumping Station for Portland Water District

Building Inspections

Use Group: U **Type:** N/A
Utility - sewer pumping station
Exterior at grade
MUBEC/IBC 2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Setbacks and Footings Prior to Pouring
Electrical - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-01510	Date Applied For: 06/25/2015	CBL: 087 U001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Wastewater Pumping Station	Proposed Project Description: Installing an emergency standby generator on concrete pad (5'8" x 10'2") to provide backup power in case of power failure (Located on property known as 5 City Point Road)			
Dept: Zoning Status: Approved w/Conditions Reviewer: Ann Machado Approval Date: 07/30/2015 Note: - Portland Water District has an easement 30' x 50' to construct and maintain a pumping station on this property Ok to Issue: <input checked="" type="checkbox"/> - IR-2 Zone - no noise restrictions - will be tested Tuesday mornings for no longer than 30 minutes - estimated sound level is 66 dB - located in Shoreland Zone - Pumping station at least 166' from highest annual tide Conditions: 1) Generator should only be tested weekdays between the hours of 9 a.m. and 5 p.m.				
Dept: Building Inspection Status: Approved w/Conditions Reviewer: Jeanie Bourke Approval Date: 07/30/2015 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) A separate permit is required for electrical installations				