



GLASS RAILING WALL:  
GLAZING SHALL BE TESTED IN ACCORDANCE  
WITH CPSC 16 CFR PART 1201, AND  
COMPLY WITH THE CRITERIA FOR CATEGORY II.  
CONNECTIONS TO BE DESIGNED TO RESIST  
A UNIFORM WIND PRESSURE  
OF 50#/SQ.FT. APPLIED TO THE GLAZING

18'-6"  
APPROXIMATE OVERALL WIDTH OF DECK  
(ACTUAL SIZE DETERMINED BY PLACEMENT  
OF 4X6 DECK SUPPORT POSTS IN 2ND FLOOR WALLS)

HORIZONTAL P.T. 2X12  
SKIRTING WITH 1" GAP

+13'-1" ROOFTOP DECK FLOOR

+11'-5" TOP OF FLAT ROOF

0'-0" SECOND FLOOR FLOOR

-0'-4 1/2" UPPER LANDINGS

-14'-3 1/4" NORTH AVERAGE GRADE

(A) Proposed West Elevation  
1/4" = 1'-0"



**Rachel Conly**  
Architectural Design

26 Sterling Street  
Peaks Island, Maine 04108  
207.766.5625

Proposed  
West  
Elevation

PROJECT

Belden Residence  
141 Island Ave.  
Unit #6  
Peaks Island, ME

DATE  
02.05.15

REVISED

SCALE  
1/4" = 1'-0"

DRAWN BY  
Rachel &  
Harvey

NOTES

**A8**