

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION


Maine Department of Inland Services
 Division of Health & Engineering, Station 10, SHS
 (207) 287-6672 FAX (207) 287-4172

Town, City, Plantation: **PORTLAND, PEAKS ISLAND**
 Street, Road, Subdivision: **39 UPPER A STREET**
 Owner's Name: **THERESA BUTKUS**

NOTE: THOROUGHLY SCARIFY UNDER
 EXISTING DISPOSAL FIELD, SHOULDER
 AREA, & FILL EXTENSION AREA PRIOR
 TO FILL PLACEMENT, THEN BLEND FIRST
 LIFT OF FILL INTO EXISTING SOIL
 SURFACE TO PROMOTE MIXING

SUBSURFACE WASTEWATER DISPOSAL PLAN


SCALE 1" = 20 FT.



FILL REQUIREMENTS		CONSTRUCTION ELEVATIONS		ELEVATION REFERENCE POINT	
Depth of Fill (Upslope)	: 29" - 31"	Finished Grade Elevation	SEE	Location & Description	BOTTOM OF WINDOW TRIM, 32" ABOVE BOTTOM OF SIDING (33" ABOVE GRADE)
Depth of Fill (Downslope)	: 30" - 31"	Top of Distribution Pipe or Proprietary Device	DETAIL	Reference Elevation is:	0.0' or -----
DEPTH(S) AT CROSS-SECTION (shown below)		Bottom of Disposal Area	BELOW		

DISPOSAL AREA CROSS SECTION

SCALE:
 VERTICAL: 1" = 5 FT
 HORIZONTAL: 1" = 5 FT



Albert Frick
 Site Evaluator Signature

163
 SE

8/5/2016
 Date

Page 3 of 3
 MHE-200 Rev 10/02