SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Maine Department of Human Services
Division of Health Engineering, Station
(207) 287-5672 FAX (207) 287

CITY OF PORTLAND, MAINE RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 03/13/17

Town, City, Plantation	Street, Road Subdivision	Owner's Name
PORTLAND, PEAKS ISLAND	39 UPPER A STREET	THERESA BUTKUS

SITE PLAN — Scale 1" = 40 Ft. or as shown



SITE LOCATION PLAN (Attach Map from Maine Atlas Recommended)

SOIL DESCRIPTION AND CLASSIFICATION (Location of Observation Holes Shown Above)

Observation Hole TP 1 ☐ Test Pit ☐ Boring
_____" Depth of Organic Horizon Above Mineral Soil

Depth Below Mineral Soil Surface (inches)	Texture	Consistency	Color	Mottling
0	CHANNERY SANDY LOAM	FRIABLE	DARK BROWN	
10			YELLOW BROWN	NONE EVIDENT
20		REFUSAL IN LARGE ROCK OR BEDROCK		
30				
40				
50				

Soil Classification		Slope	Limiting Factor	
2	AIII	0-3 %	18"	☐ Ground Water ☐ Restrictive Layer ■ Bedrock ☐ Pit Depth
Profile	Condition			

Observation Hole TB5 ☐ Test Pit ■ Boring
_____" Depth of Organic Horizon Above Mineral Soil

Depth Below Mineral Soil Surface (inches)	Texture	Consistency	Color	Mottling
0				
10	TB A = 20" TO REFUSAL / BEDROCK			
20	TB B = 25" TO REFUSAL / BEDROCK			
30	TB C = 17" TO REFUSAL / BEDROCK			
40	TB D = 24" TO REFUSAL / BEDROCK			
50	TB E = 26" TO REFUSAL / BEDROCK			

Soil Classification		Slope	Limiting Factor	
		%	"	☐ Ground Water ☐ Restrictive Layer ☐ Bedrock ☐ Pit Depth
Profile	Condition			

Albert Frick — Site Evaluator Signature

K3 — SE #

8/5/2016 — Date

ALBERT FRICK ASSOCIATES – 95A COUNTY ROAD ROAD GORHAM, MAINE 04038 – (207) 839-5563