






FIRE SPRINKLER PLAN – BASEMENT FLOOR

SCALE: 1/4"=1'-0"
 AREA PROTECTED: 1360 SQ.FT.
 FINISH FLOOR ELEVATION : 100'-0"
 COLOR CODE:

Sprinkler Head Schedule				
Symbol	Count	Thread	K-Factor	Description
⊙	8	1/2"	4.9	175' WHITE RECESSED PENDENT TY2234 LFI
○	4	1/2"	4.2	200' BRASS UPRIGHT TY2131 TY-FR8
12 = Total Number of Heads this floor				




HEAD DETAILS
 SCALE: N.T.S.




- LEGEND FOR NFPA 13D SPRINKLER SYSTEM
- GOULDS GT-20, 2 H.P., 30 GPM @ 53.69 PSI PUMP 230/1/60
 - 175 PLASTIC GALLON WATER STORAGE TANK (2) (31"x61")
 - 1 1/2" BALL VALVE (NORMALLY OPEN WITH LOCK)
 - 1 1/2" SWING CHECK VALVE
 - 30-50 PUMP CONTROL SWITCH (230 VOLTS)
 - 1 1/2" POTTER VSR-SF FLOW SWITCH
 - BOILER DRAIN VALVE (AUX. DRAIN)
 - 3/4" PRESSURE GAUGE W/ 1/4" 3-WAY GLOBE VALVE
 - 1" MAIN DRAIN & ALARM TEST. VALVE
 - ELECTRIC BELL (LOCATION TO BE APPROVED BY OWNER)
 - 1 1/2" VENT CAP
 - 1/2" COPPER BALL VALVE FOR TANK FILL LINE (NORMALLY CLOSED)
 - 1 1/2" GROOVED COUPLING
 - 1 1/2" GROOVED COUPLING
 - NFPA 13D PUMP CONTROL PANEL
 - 1 1/2" X 1 1/2" REDUCING COUPLING

ALL WIRING TO BE DONE BY OTHERS




HANGER # 18



CPVC HANGER

HANGER DETAILS
 NOT TO SCALE

ALL HANGERS TO BE PROVIDED AND
 INSTALLED AS PER NFPA # 13D
 3/8" ROD FOR 1" TO 4" PIPE




DIMENSIONS AND MOTOR DATA											
MODEL NO.	GT07	GT10	GT15	GT20	GT30	GT07S	GT10S	GT15S	GT20S	GT30S	
HP	1/4	1/2	3/4	1	1 1/2	1/4	1/2	3/4	1	1 1/2	
LENGTH "L"	19 3/16	19 1/8	21 3/4	21 1/8	21 1/8	19 3/16	19 1/8	21 3/4	21 1/8	21 1/8	
WIDTH	8 1/4										
HEIGHT	8 1/4										
WT. (lbs.)	48	52	60	65	76	49	52	55	69	71	
PHASE	SINGLE					THREE					
MOTOR DATA											
60 HERTZ SINGLE PHASE	115/230 VOLT										
PUMP MODEL NO.	GT20										
HORSE-POWER	1/2										
R.P.M.	3500										

3 1/2"

5 1/4"

SECTION



0 GPM = 54.99 PSI 30 GPM = 53.69PSI 70 GPM = 38.87 PSI
 10 GPM = 54.56 PSI 40 GPM = 52.39 PSI 80 GPM = 32.04 PSI
 20 GPM = 54.13 PSI 60 GPM = 45.03 PSI

- NOTE
- ALL ELECTRICAL WIRING, PAINTING, AND INSULATING TO BE DONE BY OTHERS
 - SYSTEM TANK SIZE EQUALS GPM DEMAND (34.31) FOR TWO HEADS TIMES TEN MINUTES = 343 GALLONS
 - TOTAL STORED WATER SUPPLY: 350 GALLONS

HYDRAULIC-SYSTEM	
THIS BUILDING IS PROTECTED BY A HYDRAULICALLY DESIGNED AUTOMATIC SPRINKLER SYSTEM.	
LOCATION: OFFICE	
NFPA #13D	
BASIS OF DESIGN:	22.9
1. GPM PER HEAD	
2. NUMBER OF HEADS CALCULATED	1
SYSTEM DEMAND AT BASE:	
1. WATER FLOW RATE (GPM)	22
2. RESIDUAL PRESSURE AT PUMP (PSI)	49

HYDRAULIC DATA NAMEPLATES
 TO BE MOUNTED AT SYSTEM RISER
 NOTE: HIGHEST SPRINKLER IS 126.0'
 ○ = HYDRAULIC REFERENCE POINT

APPLYING CEMENT, SETTING AND CURE TIMES
 Prepare pipe by beveling outside end 10' to 15', deburring end and wiping away excess fillings. Apply a heavy, even coat of solvent cement to the outside end of the pipe, a medium coat to the inside of the fitting socket and for pipe sizes larger than 1", apply a second coat to the end of the pipe. Beveling allows the cement to remain on the fitting socket inside wall.

A bead of solvent cement should be evident around the pipe and fitting juncture. If this bead is not continuous around the socket shoulder, it may indicate that insufficient cement was applied.

Wipe off excess cement on the outside of the joint. The solvents will evaporate, but the solvent cement inside the fitting will stay there.

WARNING
 Avoid applying too much cement. Do not allow the cement to drip beyond the bottom of fitting socket. Excessive cement on the pipe and/or fitting can result in decreasing the overall strength of the pipe and/or fitting and may cause cracks when pressure is applied. Failure to comply could result in property damage due to leaks.

Solvent cement set and cure times are a function of pipe size, temperature, relative humidity, and tightness of fit. Drying time is faster for drier environments, smaller pipe sizes, high temperatures, and tighter fits. The assembly must be allowed to set, without any stress on the joint, for 1 to 5 minutes, depending on the pipe size and temperature. Following the initial set period, the assembly can be handled carefully avoiding significant stresses to the joint. Refer to the cure time tables for minimum cure times prior to pressure testing.

Store cement in a warmer area when not in use and make sure they remain fluid. Do not allow the cement to freeze or become 'jelly-like'. Gelled cement shall be discarded.

Sprinkler heads shall be installed only after all the CPVC pipe and fittings, including the sprinkler head adapters, are solvent welded to the piping and allowed to cure for a minimum of 30 minutes. Sprinkler head fittings should be visually inspected and probed with a wooden dowel to insure that the water way and threads are clear of any excess cement.

It is an unacceptable practice to thread the sprinkler head into the adapter fitting prior to cementing the adapter to the drop.

Once an installation is completed and cured, per the appropriate table, the system should be tested with water at 200 psi for 2 hours, or at 30 psi in excess of the maximum pressure when the maximum pressure to be maintained in the system is in excess of 150 psi, in accordance with the requirements established by NFPA 13. Sprinkler systems in one and two family dwellings and mobile homes may be tested at line pressure in accordance with the requirements established by NFPA 13D. When pressure testing, the sprinkler system shall be filled with water and air bled from the highest and farthest sprinkler head before test pressure is applied. Air or compressed gas should never be used for pressure testing. If a leak is found, the fitting must be cut out and discarded. A new section can be installed using couplings or a union. Unions should be used in accessible area only.


NOTES:
 Listings and approvals do not cover any painted CPVC fire sprinkler products. Water-based acrylic latex paint is the preferred and recommended paint to be used on Blazemaster CPVC pipe and fittings. Oil or solvent-based paints may be chemically incompatible with Blazemaster CPVC.

Teflon thread tape is the recommended sealant for threaded connections to CPVC fire sprinkler products. When using Datex Great White Thread Sealant, it should be applied to male threads only.

Firestop systems such as Hilti FS-One have been found to be compatible with CPVC fire sprinkler products. A list of these Firestop systems can be found along with approved thread sealants on-line at www.blazemaster.com. Use only those products that have been approved.

CURE TIMES WITH ONE STEP SOLVENT CEMENT			
200 psi (MAXIMUM) TEST PRESSURE			
PIPE SIZE inches	Ambient Temperature During Cure Period		
	60°F to 120°F	40°F to 59°F	0°F to 39°F
3/4"	45 min.	1.5 hr.	24 hr.
1"	45 min.	1.5 hr.	24 hr.
1-1/4"	1.5 hr.	16 hr.	120 hr.
1-1/2"	1.5 hr.	16 hr.	120 hr.
2"	6 hr.	36 hr.	See Note 1
2-1/2"	8 hr.	72 hr.	See Note 1
3"	8 hr.	72 hr.	See Note 1

Note 1 For these sizes, the solvent cement can be applied at temperatures below 40°F, however, the sprinkler system temperature must be raised to a temperature of 40°F or above and allowed to cure per the above recommendations prior to pressure testing.



Thread the sprinkler into the adapter fitting only after the recommended cure time

CPVC SPRINKLER HEAD
 INSTALLATION DETAIL
 NOT TO SCALE

USE "OATEY" GREAT WHITE PIPE JOINT COMPOUND OR TEFLON TAPE ON ALL STEEL OR BRASS PIPE THREADS.

"SUBMITTAL DRAWING"

GENERAL NOTES		DATE	REVISIONS	REQUIRED APPROVALS	130 ISLAND AVE. PEAKS ISLAND PORTLAND, ME	FIRE SPRINKLER PLANS & DETAILS
SPRINKLER SYSTEM INSTALLATION TO COMPLY WITH NFPA PAMPHLET # 13D (2010 EDITION)				OWNER / ARCHITECT STATE FIRE MARSHAL PORTLAND FIRE DEPARTMENT		
OWNER TO PROVIDE SUFFICIENT HEAT THRU-OUT THE BUILDING TO PREVENT FREEZING OF WATER FILLED SPRINKLER PIPING AND EQUIPMENT.				DRAWN BY RJP NICET LEVEL CERT.#	CONTRACT WITH: JIM GREENWELL	DWG. NO. 1 OF 2
BASEMENT PIPING SHALL BE EXPOSED BLACK SCH. 40 STEEL PIPE WITH DUCTILE IRON FITTINGS (C = 120).				CHECKED BY WAF NICET LEVEL III CERT.# 095574		
ALL CONCEALED PIPE TO BE CPVC PLASTIC PIPE JOINED WITH GLUED CPVC FITTINGS C=150				CONTRACTOR LICENSE # 101 CONTRACTOR RMS # 368	EASTERN FIRE PROTECTION AUBURN/LEWISTON INDUSTRIAL AIRPARK, AUBURN, MAINE 04210	JOB NUMBER AU-4841-11
1. SPRINKLERS ARE NOT REQUIRED IN THE FOLLOWING AREAS AS PER NFPA 13D: A. BATHROOMS NOT EXCEEDING 55 SQ. FT. WITH NON-COMBUSTIBLE CONSTRUCTION & FIXTURES B. SMALL CLOSETS LESS THAN 24 SQ. FT. IN AREA WITH THE LEAST DIMENSION NOT EXCEEDING 3'0" C. OPEN ATTACHED PORCHES,GARAGES AND OUTSIDE STORAGE AREAS D. CRAWL SPACES AND ATTICS NOT USED FOR LIVING PURPOSES						
					SCALE AS NOTED	DATE 02/14/2011