

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Maine Department of Human Services
Division of Health Engineering, Station 10 SHS
(207) 287-5672 FAX (207) 287-4172


Town, City, Plantation
PORTLAND, PEAKS ISLAND

Street, Road Subdivision
76 CENTRAL AVENUE, LOT 4

Owner's Name
GEORGE PURTELL

SITE PLAN Scale 1" = 100 Ft. or as shown

SITE LOCATION PLAN
(Attach Map from Maine Atlas for New System Variance)



SOIL DESCRIPTION AND CLASSIFICATION (Location of Observation Holes Shown Above)

Observation Hole **TP 1** Test Pit Boring
" Depth of Organic Horizon Above Mineral Soil

| DEPTH BELOW MINERAL SOIL SURFACE (inches) | Texture | Consistency | Color | Mottling |
|---|-------------------|---------------|----------------------|-----------------|
| 0 | SANDY LOAM | | DARK BROWN | |
| 10 | | FRIABLE | DARK YELLOWISH BROWN | |
| 20 | LOAMY SAND | | YELLOWISH BROWN | |
| 30 | | | | FEW FAINT |
| 40 | LOAMY SAND & SAND | SOMEWHAT FIRM | OLIVE BROWN | COMMON DISTINCT |
| 50 | | | | |

Observation Hole Test Pit Boring
" Depth of Organic Horizon Above Mineral Soil

| DEPTH BELOW MINERAL SOIL SURFACE (inches) | Texture | Consistency | Color | Mottling |
|---|---------|-------------|-------|----------|
| 0 | | | | |
| 10 | | | | |
| 20 | | | | |
| 30 | | | | |
| 40 | | | | |
| 50 | | | | |

Soil Classification **3 C** Slope **6-7** Limiting Factor **24"**

Profile **3** Condition **C**

Ground Water Restrictive Layer Bedrock Pit Depth

Soil Classification _____ Slope _____ Limiting Factor _____

Profile _____ Condition _____ %

Ground Water Restrictive Layer Bedrock Pit Depth

Albert Frick
Site Evaluator Signature

163
SE

10/2/2014
Date