

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 2013-00697	Date Applied For: 04/10/2013	CBL: 088 M007001
---------------------------------	--	----------------------------

Location of Construction: 191 BRACKETT AVE, Peaks Islan	Owner Name: VONREYN TIMOTHY J & SUSA	Owner Address: 191 BRACKETT AVE	Phone:
Business Name:	Contractor Name: Revision Energy LLC	Contractor Address: 142 Presumpscot street Portland	Phone (207) 323-1805
Lessee/Buyer's Name	Phone:	Permit Type: Alterations - Dwellings	

Proposed Use: Single Family	Proposed Project Description: Installing 12 solar panels to roof of building connecting to utility grid & installing air source heat pump
---------------------------------------	---

Dept: Zoning **Status:** Approved **Reviewer:** Ann Machado **Approval Date:** 05/02/2013
Note: **Ok to Issue:**

Dept: Building **Status:** Approved w/Conditions **Reviewer:** Jon Rioux **Approval Date:** 05/08/2013
Note: **Ok to Issue:**

- 1) Separate permits are required for any electrical: plumbing, sprinkler, fire alarm, HVAC systems, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.
- 2) Permit approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.
- 3) Roof-mounted collectors. The roof shall be constructed to support the loads imposed by roof-mounted solar collectors. Roof-mounted solar collectors that serve as a roof covering shall conform to the requirements for roof coverings in Chapter 9 of this code. Where mounted on or above the roof coverings, the collectors and supporting structure shall be constructed of noncombustible materials or fire-retardant-treated wood equivalent to that required for the roof construction.

All system components containing fluids shall be protected with pressure: temperature, backflow and vacuum relief, from freezing, (prohibited heat transfer of fluids), and labeled in compliance with Chapter 23 of the IRC, 2009 (MUBEC).

M2301.2.7 Roof and wall penetrations. Roof and wall penetrations shall be flashed and sealed in accordance with Chapter 9 of this code to prevent entry of water, rodents and insects.